# **Panasonic**

Safety Control Unit

**SF-C21** 

# **Instruction Manual**



(MEMO)

Thank you for purchasing Panasonic Industrial Devices SUNX's Safety Control Unit **SF-C21**. Please read this instruction manual carefully and thoroughly for the correct and optimum use of this device.

Kindly keep this manual in a convenient place for quick reference.

This device is a safety control unit for machines.

This manual is for the personnel who have undergone suitable training, have knowledge of safety of machines and knowledge of electricity (are electric workers or have knowledge equivalent to that of the workers), and

- who are responsible for the introduction of this device.
- who design the system using this device,
- · who install and connect this device,
- who manage and operate a plant using this device, and
- who are qualified and responsible for each of the phases of design, manufacture, installation, operation, maintenance or disposal.

Please fully understand "Safety Standards" introduced in this instruction manual and properly handle the equipment with paying attention to the safety.

#### **Notes**

- 1) All the contents of this instruction manual are the copyright of the publishers, and may not be reproduced (even extracts) in any form by any electronic or mechanical means (including photocopying, recording, or information storage and retrieval) without permission in writing from the publisher.
- 2) The contents of this instruction manual may be changed without prior notice for further improvement of the device.
- 3) Though we have carefully drawn up the contents of this instruction manual, if there are any aspects that are not clear, or any error that you may notice, please contact our local Panasonic Industrial Devices SUNX office of the nearest distributor.
- 4) English and Japanese are original instructions.
- 5) Windows is a registered trademark of U.S. Microsoft Corporation and other countries.
- 6) All other companies and product names are trademarks or registered trademarks of their respective companies.

# **Contents**

Chapte	er 1 Introduction ·····	7
1-1	Attention Marks	7
1-2	Safety Precautions ·····	7
1-3	Applicable Standards / Regulations · · · · · · · · · · · · · · · · · · ·	9
1-4	Confirmation of Packed Contents ······	9
Chapte	er 2 Before Using This Device ·····	10
2-1	Features ·····	10
2-2	Part Description · · · · · · · · · · · · · · · · · · ·	12
2-3	Terminal Arrangement ······	13
2-4	Confirming Product Information · · · · · · · · · · · · · · · · · · ·	14
2-5	Mounting	15
	2-5-1 Installing Direction ·····	15
	2-5-2 Installation Space ·····	16
	2-5-3 Installation to and Removal from a DIN Rail	18
	2-5-4 Installing the Unit Directly in a Control Panel Using Screws ······	19
	2-5-5 Installation Environment	····· 19
2-6	Wiring ·····	20
	2-6-1 Power Supply Unit ·····	20
	2-6-2 I/O Circuit Diagrams·····	21
	2-6-3 Connecting to the Terminal Block	23
	2-6-4 Connection of Safety Devices ·····	24
Chapte	er 3 Functions·····	25
3-1	Safety Input ·····	25
	3-1-1 Contact Input Mismatch Allowable Time ·····	25
3-2	Control Output	26
	3-2-1 Response Time · · · · · · · · · · · · · · · · · · ·	
3-3	Auxiliary Output ·····	26
3-4	Interlock (Reset) ·····	27
	3-4-1 Overall reset·····	
	3-4-2 Partial Reset·····	28
3-5	Releasing Lockout·····	29
3-6	External Device Monitor · · · · · · · · · · · · · · · · · · ·	30
3-7	Test Input ·····	30
3-8	MODBUS Communication (Non-safety) ······	31
	3-8-1 MODBUS RTU Specification	31
	3-8-2 Wiring Example	32
	3-8-3 Function Code ·····	
	3-8-4 Error Codes·····	
	3-8-5 Address Map ·····	
	3-8-6 Message Format ·····	
	3-8-7 Function Code ·····	
	USB Communication ·····	
3-10	) Logic Selection Function ·····	39
3-11	OFF Delay Time Selection Function·····	47
3-12	2 Logic Settings by Software Tool······	47
3-13	B Logic Manual Stop / Start Function·····	48

Chapte	er 4 Setting of Logics······	····49
4-1	Types and Settings of Logics ······	···· 49
	4-1-1 Factory Setting······	49
4-2	Preparation for Logic Setting	50
	4-2-1 Turning ON the Power · · · · · · · · · · · · · · · · · · ·	50
	4-2-2 Portions Used in Settings ······	50
4-3	Operation in RUN Mode and the Display	···· 51
	4-3-1 Operation and Display During Normal Operation · · · · · · · · · · · · · · · · · · ·	51
	4-3-2 Display When an Error Occurs ······	52
4-4	Setting of Logics and OFF Delay Time	53
	4-4-1 Flowchart of Logic and OFF Delay Time	53
	4-4-2 Operation Procedure for Setting Logic and OFF Delay Time	54
4-5	Change Password ······	60
	4-5-1 Flowchart of Change Password ······	60
	4-5-2 Operation Procedure for Change Password ······	61
Chapte	er 5 Software Tool·····	66
5-1	System Configuration	66
5-2	Required System Specifications ·····	67
	5-2-1 Operating System·····	67
	5-2-2 PC Specifications ·····	67
	Installation	
5-4	Uninstallation ·····	67
5-5	Connection of this Device and a PC ······	68
	5-5-1 Connection to "Monitor Mode" · · · · · · · · · · · · · · · · · · ·	68
	5-5-2 Connection to "Transfer Mode"	
	5-5-3 Setting to "Monitor Mode" after the End of Transfer	70
	5-5-4 Disconnection of this Device from a PC	70
	5-5-5 Initialization of this Device ·····	70
5-6	Startup and End of Software Tool ·····	···· 71
	5-6-1 Startup Software Tool ·····	71
	5-6-2 End of Software Tool · · · · · · · · · · · · · · · · · ·	
5-7	New / Save / Print of a File · · · · · · · · · · · · · · · · · · ·	
	5-7-1 Create New File · · · · · · · · · · · · · · · · · · ·	74
	5-7-2 Open Sample Logic ·····	76
	5-7-3 Open a Recent File	78
	5-7-4 Upload Logic from this Device ······	80
	5-7-5 Saving a File ·····	81
	5-7-6 Download Logic to Device ·····	83
	5-7-7 Print·····	
	Each Part Name of the Software Tool and Basic Operation · · · · · · · · · · · · · · · · · · ·	
5-9	Creating and Editing a Logic, and Saving a File and Transferring it to	
	Device ····	
	5-9-1 Creating and Editing Logic ·····	88
	5-9-2 Saving a Logic File and Transferring it to this Device ······	88
5-10	)Create a Logic······	89
	5-10-1 Create a Logic ·····	89
	5-10-1-1 Set Input Lock······	89
	5-10-1-2 Set Control Block 1 ·····	90
	5-10-1-3 Create a Circuit ······	
	5-10-2 Example of a Logic Using Control Block 1 / 2 ······	92

5-10-3 Example of a Logic Using Control Block 1 / 2 / 3 ·····	93
5-11 Select Input ······	···· 94
5-11-1 Types of Inputs · · · · · · · · · · · · · · · · · · ·	
5-11-2 Setting of Contact Input Mismatch Allowable Time	95
5-12 Select Control · · · · · · · · · · · · · · · · · · ·	
5-13 Interlock block ·····	
5-14 Auxiliary Output Block ······	98
5-15 Mode switching block ······	99
5-15-1 Mode Switching · · · · · · · · · · · · · · · · · · ·	99
5-15-2 Simulation Mode·····	
5-16 Output Setting, OFF Delay and ON Delay Setting ·····	⋯ 101
5-17 Detailed Settings (Muting) ·······	··· 101
5-18 Verify Files on the Device and PC	⋯ 101
5-19 Configuration Check ······	⋯ 102
5-20 Highlighting OFF ······	·· 103
5-21 Device Information	⋯ 103
5-21-1 General ·····	⋯ 103
5-21-1-1 Change Password ······	⋯ 103
5-21-1-2 Initialize Settings ·····	⋯ 104
5-21-2 Configuration Log ······	⋯ 104
5-21-3 Error Log······	⋯ 104
5-22 Communication Settings · · · · · · · · · · · · · · · · · · ·	⋯ 105
5-23 Monitor	⋯ 106
5-24 Help	⋯ 107
5-24-1 Language·····	⋯ 107
5-24-2 Manual	
5-24-3 Version Information · · · · · · · · · · · · · · · · · · ·	⋯ 107
Chapter 6 Maintenance	108
6-1 Daily Inspection ·····	108
6-2 Periodic Inspection (Every Six Months)·····	·· 108
6-3 Inspection after Maintenance of this Device	·· 109
Objection 7. Translation in	440
Chapter 7 Troubleshooting	110
Chapter 8 Specifications / Dimensions · · · · · · · · · · · · · · · · · · ·	112
8-1 Specifications ·······	112
8-2 Dimensions ······	112
0-2 Dillicusions	. 113
Chapter 9 Others ·····	116
9-1 Glossary······	116
9-2 CE Marking Declaration of Conformity ······	117
5 - 5 - Marking Decidration of Combining	117

#### 1-1 Attention Marks

This instruction manual employs the following attentions marks "A WARNING," "A CAUTION" depending on the degree of the danger to call operator's attention to each particular action. Read the following explanation of these marks thoroughly and observe these notices without fail.

MARNING If you ignore the advice with this mark, death or serious injury could result.

⚠ CAUTION If you ignore the advice with this mark, injury or material damage could result.

<Reference> It gives useful information for better use of this device.

Note that items described in "A CAUTION" may lead to serious results, depending on situations.

Be sure to observe these important items described.

# 1-2 Safety Precautions

- Use this device as per its specifications. Do not modify this device since its functions and capabilities may not be maintained and it may malfunction.
- This device has been developed / produced for industrial use only.
- Use of this device under the following conditions or environments is not presupposed. Please consult us if there is no other choice but to use this device in such an environment.
  - 1) Operating this device under conditions or environments not described in this manual.
  - 2) Using this device in the following fields: nuclear power control, railroad, aircraft, auto mobiles, combustion facilities, medical systems, aerospace development, etc.
- In case of installing this device to a particular machine, follow the safety regulations in regard to appropriate usage, mounting (installation), operation and maintenance. The users including the installation operator are responsible for the introduction of this device.
- Note that this device may be damaged if it is subject to a strong shock (if it is dropped onto the floor, for example).
- Use this device by installing suitable protection equipment as a countermeasure for failure, damage, or malfunction of this device.
- Before using this device, check whether the device performs properly with the functions and capabilities as per the design specifications.
- In case of disposal, dispose this device as an industrial waste.

# **⚠ WARNING**

### ♦ Machine designer, installer, employer and operator

- The machine designer, installer, employer and operator are solely responsible to ensure that all applicable legal requirements relating to the installation and the use in any application are satisfied and all instructions for installation and maintenance contained in the instruction manual are followed.
- Whether this device functions as intended to and systems including this device comply with safety regulations depends on the appropriateness of the application, installation, maintenance and operation. The machine designer, installer, employer and operator are solely responsible for these items.

#### **◆** Engineer

• The engineer would be a person who is appropriately educated, has widespread knowledge and experience, and can solve various problems which may arise during work, such as a machine designer, or a person in charge of installation or operation etc.

#### Operator

- The operator should read this instruction manual thoroughly, understand its contents, and perform operations following the procedures described in this manual for the correct operation of this device.
- In case this device does not perform properly, the operator should report this to the person in charge and stop the machine operation immediately. The machine must not be operated until correct performance of this device has been confirmed.

#### **♦** Environment

- Do not use a mobile phone or a radio phone near this device.
- This device starts the performance after 2 seconds from the power ON. Have the control system started to function with this timing.
- Do not install this device in the following environments.
  - 1) The device is exposed to direct sunlight
  - 2) Dew condensation may occur due to sudden changes in temperature
  - 3) The ambient air contains corrosive or flammable gas
  - 4) There is a high level of dust, metallic dust, or salt content
  - 5) The device may be exposed to organic solvents such as benzene, thinner, or alcohol and/or strong alkaline substances such as ammonia or caustic soda, or any such substances exist in the ambient air
  - 6) The device may be directly exposed to vibration or impact or to water drops
  - 7) The device may be exposed to interference from nearby high-voltage lines, high-voltage equipment, power wires, motor equipment, an amateur radio station or other transmitter, or a device with large switching surges (the device must be placed at a distance of 100mm or greater from any interference sources)

#### Wiring

- Do not work on (connect or remove etc.) the device while the power is ON. Failure to follow this precaution could result in an electric shock.
- All electrical wiring should conform to the regional electrical regulations and laws. The wiring should be done by engineer(s) having the special electrical knowledge
- Do not run the wires together with high-voltage lines or power lines or put them in the same raceway. This can cause malfunction due to induction.
- Do not control the device only at one control output.

#### ◆ Maintenance

- When replacement parts are required, always use only genuine supplied replacement parts. Do not use a third-party part because doing so could cause the device to malfunction, possibly resulting in a death or serious injury.
- The periodical inspection of this device must be performed by an engineer having the special knowledge.
- After maintenance or adjustment, and before starting operation, test this device following the procedure specified in "Chapter 6 Maintenance."
- Clean this device with a clean cloth. Do not use any volatile chemicals.

#### Others

• Never modify this device. Failure to follow this precaution may cause the device to malfunction, possibly resulting in a death or serious injury.

# 1-3 Applicable Standards / Regulations

This device complies with the following standards / regulations.

#### <EU Directives>

EU Machinery Directive 2006/42/EC

EMC Directive 2004/108/EC

RoHS Directive 2011/65/FU

#### <European Standards>

EN 55011: 2009 +A1: 2010 Class A, EN 61000-6-2: 2005, EN 62061: 2005 (SILCL3)

EN ISO 13849-1: 2008 (Up to category 4, PLe)

#### <International Standards>

IEC 61131-2: 2007, IEC 61010-2-201: 2013, ISO 13849-1: 2006 (Up to category 4, PLe)

IEC 61508-1 to 7: 2010 (SIL3), IEC 62061: 2005 (SILCL3)

#### <Japanese Industrial Standards (JIS)>

JIS B 3502, JIS B 9705-1 (Up to category 4, PLe), JIS C 0508 (SIL3)

Regarding EU Machinery Directive, a Notified Body, TÜV SÜD, has certified with the type examination certificate.

#### <Reference>

The conformity to JIS for this device has been evaluated by ourselves.

This device conforms to the EMC Directive and the Machinery Directive. The **( (** mark on the main body indicates that this device conforms to the EMC Directive.

# **⚠ WARNING**

For the safety of the overall system and the conformity to the standards applicable in each region or country in which this device is installed, take actions on the customer's own responsibility.

### 1-4 Confirmation of Packed Contents

□ SF-C21			1 pc.

□ Quick Instruction Manual (Japanese, English)


1 pc. each language

# **Chapter 2 Before Using This Device**

#### 2-1 Features

This device is a safety control unit. This device has eight built-in preset logics that can deal with various safety systems. The logics can also be set (customizable logics).

The preset logics and customizable logics have acquired related international standards. Selecting logics and connecting safety devices can construct various safety circuits.



#### (1) Selecting preset logics and connecting various safety devices

This device incorporates eight preset logics supporting basic applications and one customizable logic that can be set freely.

#### (2) Easy setting of software tool and customizable logic

Customizable logics can easily be set in PC by using a software tool.

#### (3) Acquisition of safety certification

This unit is a safety control unit that has acquired IEC 61508 (SIL3) and ISO 13849-1 (Up to category 4, PLe).

#### (4) Safety categories 2, 3, and 4 available

Selecting logics and connecting various types of safety devices can construct systems available for Categories 2, 3, and 4 of ISO 13849-1.

### (5) Limiting of system space

More system space can be saved compared with a system using safety relay.

#### (6) Improvement of wiring work efficiency

Adopting a removal terminal block can reduce man-hours for wiring and prevent improper wiring when this device is replaced.

#### (7) Fail safe function

If a failure occur inside this device, the self-diagnosis function can detect the failure and turn OFF the output.


### (8) Enhancement of failure diagnosis

Failures, including those of safety devices in connection is diagnosed by using test pulse (monitoring of cross short fault). In addition, self-diagnosis, e.g., memory diagnosis and circuit diagnosis, is performed.

#### (9) Installation according to use applications

35mm width DIN rail or M4 round head screw (length: 12mm or more) is available for installation.

### 2-2 Part Description



Indicator name	Display	Operation
Logic selection indicator (Orange)	LOG	When logic is selected: lights up in orange Other cases: turn OFF
Delay selection indicator (Orange)	DEL	When OFF delay is selected: lights up in orange Other cases: turn OFF
Password selection indicator (Orange)	PAS	When password is selected: lights up in orange Other cases: turn OFF
7-segment indicator (Red)	_	Selected logic / OFF delay mode is displayed. In lockout state, display of error is displayed.
Input 1 to 8 indicator (Orange)	IN1, IN2, IN3, IN4, IN5, IN6, IN7, IN8	Input at ON state: lights up in orange When input turns OFF: turns OFF
Output 1 to 4 indicator (Green)	OUT1, OUT2, OUT3, OUT4	When output at ON state: lights up in green When output at OFF state: turns OFF
Auxiliary output 1 to 4 indicator (Orange)	AUX1, AUX2, AUX3, AUX4	When output at ON state: lights up in orange When output at OFF state: turns OFF
Operation indicator (Green)	RUN	When normal operation is performed: lights up in green When setting operation: turns OFF
Setting indicator (Orange)	PROG	When setting operation: lights up in orange When normal operation: turns OFF
Interlock 1 / 2 indicator (Yellow)	INT1, INT2	When interlock is effective: lights up in yellow When interlock is ineffective: turns OFF
Muting indicator (Orange)	MUTE	When output at ON state: lights up in orange When output at OFF state: turns OFF


# 2-3 Terminal Arrangement

	Terminal dimensions	Terminal No.	Terminal name	Function		
		1	IN1	Safety input 1		
		2	T1	Safety input 1 / test output		
		3	IN2	Safety input 2		
	1 4 9	4	T2	Safety input 2 / test output		
_	<u>                                   </u>	5	IN3	Safety input 3		
0	1 199	6	T3	Safety input 3 / test output		
for	; <u> </u>	7	IN4	Safety input 4		
충		8	T4	Safety input 4 / test output		
Terminal block for I/O 1		9	MUTE1	Muting indicator output 1_1		
nal	10 <u>10 0</u> 11 <u>11 0</u>	10	NC	Not connected		
Ē	12 (TO) 13 (TO)	11	INT11	Reset input 1 / test output		
<u>le</u>	14 (∏Õ	12	INT12	Reset input 1		
	15 (TO) 16 (TO)	13	AUX1	Auxiliary output 1		
		14	AUX2	Auxiliary output 2		
		15	AUX3	Auxiliary output 3		
		16	AUX4	Auxiliary output 4		
		17	IN5	Safety input 5		
		18	T5	Safety input 5 / test output		
		19	IN6	Safety input 6		
	17 18 19 19 20 20 21 22	20	Т6	Safety input 6 / test output		
7		21	IN7	Safety input 7		
<u> </u>		22	T7	Safety input 7 / test output		
for		23	IN8	Safety input 8 / test output		
첫	□ 0 23 □ 0 24	24	T8			
plo	25 0 26 26 27 0 28 0 29 0 30 0 31 0 32	25	MUTE2	Muting indicator output 1_2		
Terminal block for I/O 2		26	NC	Not connected		
E E		27	INT21	Reset input 2 / test output		
<u> </u>		28	INT22	Reset input 2		
		29	OUT1	Control output 1		
		30	OUT2	Control output 1		
		31	OUT3	Control output 2		
		32	OUT4	Some of Suput 2		
Terminal block block for in- fernal power supply	0 ∨1 0 G1	-	V1	24V Power supply for safety input		
Terminal block for ternal po supply	[∏ <b>(</b> ] G1	-	G1	ov over safety to safety input		
ock	era.	-	+	Transmission line (+)		
blc 85	1	-	-	Transmission line (-)		
inal 3-4		-	+	Transmission line (+)		
Terminal for RS-48		-	-	Transmission line (-)		
Te for		-	E	Terminal station setting		
Terminal block for ex- Terminal ternal power for RS-48! supply	V2 Q Q G2	-	V2	Power supply for control output		
Terminal block for ternal pov supply	<b>□ □ □ □ □ □</b>	-	G2	OV Power supply for auxiliary output		

When a device (such as light curtain) requiring power supply to inputs is connected, power is supplied from internal power supply. This device does not operate when power is supplied from external power supply.

# 2-4 Confirming Product Information

The product information on this device can be confirmed on the nameplate on the side of the product.



# 2-5 Mounting

# **⚠ WARNING**


- Do not touch the terminals while power is turned ON. Doing so may cause an electric shock.
- Be careful to prevent entry of foreign materials, such as chip and wire scrap into this device.
   Otherwise, this could cause fire, failure or malfunction.
- Do not disassemble or modify this device. Doing so could cause failure, malfunction, injury, or fire. When this device is repaired or modified by other than us, this device will not be covered by our guarantee.

# **⚠** CAUTION

- Do not touch the conductive parts of this device directly. Doing so could cause malfunction or failure of this device.
- Do not drop or apply strong impact on the case of this device, which is made of resin. Doing so could cause damage to it.
- Fix this device with the DIN rail or screws securely.
- Install this device on a flat surface.
   Installing it on an uneven surface applies excessive force to internal parts, resulting in a failure.
- In case of disposal, dispose this device as an industrial waste.


### 2-5-1 Installing Direction

When installing this device, make sure that it is correctly oriented. The device must be installed vertically with its indicators and terminal blocks facing the operator side in order to ensure heat dissipation.




### 2-5-2 Installation Space

In addition, make sure that the device's upper, lower, left, and right surfaces are spaced by 50mm or more from surrounding objects such as other devices and wiring ducts.




Do not install the unit above devices which generate heat such as heaters, transformers or large scale resistors.

In order to eliminate any effects from noise emission, power wires and electromagnetic devices should be kept at 100mm or more away from the surfaces of the device. When installing the unit behind the doors of the control board, be especially careful to secure clearances as above.



To connect the software tool and cables, keep a space of 170mm or more away from the installation surface of this device.




#### 2-5-3 Installation to and Removal from a DIN Rail

Compatible DIN rail models (based on JIS C 2812) - TH35-7.5Al or TH35-7.5Fe


### <Installing>

- Step 1 Press in the DIN rail stopper.
- Step 2 Fit the nail on the opposite side of the DIN rail stopper with the DIN rail.
- Step 3 Fit the DIN rail stopper side of the unit with the DIN rail by pressing it in.



#### <Removing>

- Step 1 Insert the flat-head screwdriver into the groove in the DIN rail stopper.
- Step 2 Draw out the DIN rail stopper.
- Step 3 Push up the control unit toward the opposite side of the DIN rail stopper.
- Step 4 Remove the control unit by pulling its lower side while maintaining it in the pushed-up position (step 3).




# **⚠** CAUTION

Do not attempt to pull the control unit without first drawing out the DIN rail stopper or the nail will break.

# 2-5-4 Installing the Unit Directly in a Control Panel Using Screws

The unit can be installed directly in a control panel by means of M4 pan head screws (length: 12mm or more) (purchase separately). The machine screws should be tightened with a torque of 1.2N•m or less.



#### 2-5-5 Installation Environment

For the installation environment, refer to "8-1 Specifications." Use the unit as per its specifications.

- Installation place: The unit is designed for use in a control panel.
- Ambient temperature: -10 to +55°C
- Ambient humidity: 30 to 85% RH (No dew condensation)
- Pollution degree: 2
- Overvoltage category: II or lower
- Usable altitude: 2,000m above sea level or lower

### 2-6 Wiring

# **⚠ WARNING**

Take countermeasure against the system to be applied for this device so as not to carry out the dangerous performance caused by the earth failure.

Failure to do so could cause invalid for the system stop, resulting in death or serious injury.

#### <Reference>

Use a safety relay unit or an equivalent control circuit in safety for control output 1 / 2.

### 2-6-1 Power Supply Unit

# **⚠ WARNING**

Wire correctly using a power supply unit which conforms to the laws and standards of the region where this device is to be used.

If the power supply unit is non-conforming or the wiring is improper, it can cause damage or malunction of this device.

#### <Reference>

A specialist who has the required electrical knowledge should perform the wiring.

The power supply unit must satisfy the conditions given below.


- 1) Power supply unit authorized in the region where this device is to be used.
- Power supply unit SELV (safety extra low voltage) / PELV (protected extra low voltage) conforming to EMC Directive and Low-voltage Directive (In case CE Marking conformity is required.)
- Power supply unit conforming to the Low-voltage Directive and with an output of 100VA or less.
- 4) The frame ground (F.G.) terminal must be connected to ground when using a commercially available switching regulator.
- 5) Power supply unit with an output holding time of 20ms or more.
- 6) In case a surge is generated, take countermeasures such as connecting a surge absorber to the origin of the surge.
- 7) Power supply unit corresponding to CLASS 2 (In case C-TÜV US Listing Mark conformity is required.)

### **⚠** CAUTION

When turning ON the power supply to this device, turn ON the external power supply within 30 sec. after the internal power supply is turned ON, or turn ON the external power supply first. Delay in power ON to the external power supply locks out this device, displaying " £ 2." in the 7-segment indicator (red).

# 2-6-2 I/O Circuit Diagrams

<Example: In case of using manual reset mode and external device monitor>



\*1: Wired when muting function and override function are used.

#### <Reference>

KA, KB: External device (Forced guided relay, magnetic contactor, monitored valve, etc.)

### <Output waveform [control output ON]>

When control output is turned ON, this device performs self-diagnosis of the output circuit. The output is turned into OFF status periodically. (Refer to the figure below.)


When the OFF signal is fed back, this device judges the output circuit as normal.

When the OFF signal is not fed back, this device judges either the output circuit or wiring as error, and the control output maintains OFF status.

# **⚠** CAUTION

Perform the wiring with paying attention to the input response time of the machine to be connected to this device, since the OFF signal of this device might cause malfunction.

#### <Timing chart>




## 2-6-3 Connecting to the Terminal Block

- When connecting to the terminal block, insert a solid wire or a twisted wire (lead wire) with a ferrule (rod) terminal, as shown in the figure below, into the hole till it stops. (Ferrule terminals are not included in the product package.)
- The wire is locked when it is properly inserted. However, do not to pull the wire with an excessive force or the cable may break.
- When connecting a twisted wire (lead wire) without using a ferrule terminal, insert the wire to the innermost of the connecting hole while pressing the release button.
- To remove the wire, draw it out while pressing the release button.

For a solid wire or a twisted wire (lead wire) to be used, refer to the table below.

		Ferrule terminal			Solid wire / twisted wire			
Terminal block name	Terminal block model No.	With an insulation sleeve (mm²)	Without an insulation sleeve (mm²)	Terminal length (mm)	Solid wire (mm²)	Twisted wire (mm²)	AWG	Stripped wire length (mm)
Terminal block for I/O 1	FMC 1,5/16-ST-3,5							
Terminal block for I/O 2	FINIC 1,5/10-51-5,5							
Terminal block for internal power supply	FMC 1,5/2-ST-3,5	0.25-0.75	0.25-1.5	10	0.2-1.0	0.2-1.5	24-16	10
Terminal block for RS-485	FMC 1,5/5-ST-3,5							
Terminal block for external power supply	FKC 2,5/2-ST	0.25-2.5	0.25-2.5	10	0.2-2.5	0.2-2.5	24-12	10

<sup>&</sup>lt;Terminal block> Manufactured by Phoenix Contact



### 2-6-4 Connection of Safety Devices

When wiring between this device and safety devices, perform the following two points at this device to make the wiring satisfy the conditions defined in category 3 or 4.

- Duplication of I/O wires
- Implementation of self-diagnosis function (using test pulse) (excluding semiconductor output devices such as light curtain)

The functions (input, output, auxiliary output, and reset) of this device are automatically set by selecting preset logic.

Customizable logic can be created by changing preset logic in part or in whole by using the software tool. Arbitrary logics, independent of preset logic, can also be created as customizable logics.

#### <Reference>

Logics changed by the software tool or arbitrary logics created cannot be transferred to this device if their safety cannot be retained.

# 3-1 Safety Input

This device incorporates eight safety inputs. Safety inputs are comprised of four (duplex) input blocks.

Input block 1: IN1 / IN2
Input block 2: IN3 / IN4
Input block 3: IN5 / IN6
Input block 4: IN7 / IN8

### The following diagnoses are carried out by setting input blocks:

0 0	,
Setting	With / without diagnosis (method)
2NC contact input	With diagnosis (The input devices connected to this device are diagnosed to detect earth fault, short fault to +V, or cross short fault.)
PNP semiconductor input	Without diagnosis (The input devices themselves, connected to this device, detect earth fault, short fault to +V, or cross short fault for their own outputs.)
1NO / 1NC contact input	With diagnosis (The input devices connected to this device are diagnosed to detect earth fault, short fault to +V, or cross short fault.)
1NC contact input	Without diagnosis

Devices as shown below can be connected.

- 2NC, 1NO / 1NC, or 1NC contact output type switch
- PNP transistor output sensor or switch

### <Major connectable devices>

- Emergency stop switch
- Door switch (including non-contact type)
- Light curtain
- Läser scanner
- Two-hand operation switch
- Enable switch
- Key selector switch

# 3-1-1 Contact Input Mismatch Allowable Time

If the safety input is 2NC or 1NO / 1NC, this device simultaneously monitors ON side of two safety inputs of one system ("closed" status in the case of door switch). OFF side ("open" status in the case of door switch) cannot be monitored.

	Settable range	Initial setting
Input mismatch allowable time	0 (unlimited) to 60 sec. (in units of 0.1 sec.)	1 sec.

### 3-2 Control Output

This device is equipped with two independent systems (4 outputs = 2 systems × duplication) for control outputs (PNP semiconductor outputs).

- Control output 1: OUT1 / OUT2
- Control output 2: OUT3 / OUT4
  - · When safe: ON status
  - · When not safe / When locked out: OFF status

In the same system, two outputs perform the same operation.

### 3-2-1 Response Time

The maximum response time of this device is as follows:

- OFF response (ON status → OFF status): 10ms or less
- ON response (OFF status → ON status): 100ms or less

# 3-3 Auxiliary Output

This device is equipped with four auxiliary outputs as non-safety monitor outputs. In the case of selecting preset logic, the setting is as follows:

AUX1	Negative logic of OUT1 / OUT2
AUX2	Negative logic of OUT3 / OUT4
AUX3	Reset trigger output
AUX4	Lockout output

Each auxiliary output operation can be changed to the following output operation by using the software tool.

For details, refer to "Chapter 5 Software Tool."

- Positive logic output or negative logic output of OUT1 / OUT2
- Positive logic output or negative logic output of OUT3 / OUT4
- Output A / B / C / D of diagnosis results of input block 1 / 2 / 3 / 4
- Output E / F / G of diagnosis results of internal logical circuit
- Reset trigger output
- Lockout output
- Muting indicator output
- Monitor output of IN1 to 8
- Normally OFF

# 3-4 Interlock (Reset)

### **↑** CAUTION

When the safety input condition of this device is satisfied, the control outputs turned into ON status in the case of auto reset setting. To prevent unexpected startup of the machine, secure safety for the overall system.

The reset function of this device is set by selection of preset logic and wiring.

The software tool is available for selecting the overall reset or partial reset. For partial reset, manual reset or auto reset is selectable.

### 3-4-1 Overall Reset

Overall reset: preset logic No.1, 2, 3, 6, 7, and 8

The outputs of two systems of this device are reset by one operation.

- Manual reset: Momentary type switch is connected to between INT11 and INT12.
  - Resetting operation can be performed by switching the switch contact from "Close" to "Open."
- Auto reset : INT21-INT22 is short-circuited.

If between INT21 and INT22 is not short-circuited when power is turned ON, manual reset is automatically selected.

#### <Overall reset (manual start)>



With external device monitor



Without external device monitor

### <Overall reset (auto start)>



With external device monitor



Without external device monitor

#### 3-4-2 Partial Reset


Partial reset: Preset logic Nos. 4 and 5

Each of the outputs of two systems of this device is reset individually.

At three time of partial reset, INT11-INT12 and INT21-INT22 function are reset terminal for output control 1 (OUT1 / 2) and reset terminal for output control 2 (OUT3 / 4), respectively.

The Preset logic of this device sets manual reset. Change to auto reset can be made using software tool.

- Manual reset: Momentary type switch is connected to between INT11 and INT12 and between INT21 and INT22. Resetting operation can be performed by switching the switch contact from Close to Open.
- Auto reset : Short-circuit is made between INT11 and INT12 and between INT21 and INT22.



# 3-5 Releasing Lockout

Lockout is always released after source of error has been removed.

Lockout is released by manually operating the switch connected to between INT11 and INT12.

 Overall reset (manual start): The reset switch functions as a lockout release switch. Switching the switch from "Close" to "Open" can release lockout.







With external device monitor

Without external device monitor

Overall reset (auto start)

:Momentary type switch is connected to between INT11 and INT12.

When this device is put in lockout status, the switch functions as a lockout release switch.

Switching the switch from "Close" to "Open" can release lockout.

#### <Reference>

When INT11-INT12 and INT21-INT22 are simultaneously "Closed" during overall reset (auto start), "Reset input circuit error" turns this device into lockout status. In this case, " F 7" appears in 7-segment indicator (red).

In this case, release lockout by operating the switch again to switch "Close" to "Open."



With external device monitor



Without external device monitor

Partial reset (auto start)

:Alternate type switch is connected to between INT11 and INT12. Switching "from Open to Close to Open" can release lockout. After the release of lockout, set the switch to "Close."



With external device monitor



Without external device monitor

After the release of lockout, the operation is performed as follows:

- Manual reset: Manual reset turns the control output into ON status.
- Auto reset : Auto reset turns the control output into ON status.

# **A CAUTION**

When the safety input condition of this device is satisfied, release of lockout turns the control output into ON status in the case of auto reset setting. To prevent unexpected startup of the machine, secure safety for the overall system.

### 3-6 External Device Monitor

Operation status of the external devices connected to the control output of this device is monitored.

The NC contacts of the external devices are connected in series between INT11 and INT12 and between INT21 and INT22.

Refer to "3-4 Interlock (Reset)" and "3-5 Releasing Lockout".

### 3-7 Test Input

This is used for "Check" required in control category 2 of ISO 13849-1.


When test input is effective, the control output is turned into OFF status.

This function is not incorporated into preset logic. This function is used for setting with the software tool. Refer to "5-11-1 Types of Inputs".


The switch for 1NC contact or PNP semiconductor output (normally set to ON) is connected.

- Contact "Close" or output ON: Test input invalid
- Contact "Open" or output OFF: Test input valid

### <Manual reset>



#### <Auto reset>



# 3-8 MODBUS Communication (Non-safety)

### **⚠ WARNING**

Communication information is not available for safety control.

Using MODBUS RTU protocol, PLC, etc., can obtain monitor information (safety input status, control output status, error information, error description, and error log) from this device. Master station (PLC, etc.) issues a command (command message) to the slave station (this device), and the slave station makes a response (response message) according to the command. For this device, up to eight units can be connected as slave stations.

The communication settings are configured by using DIP switches for RS-485 on the bottom of this device or software tool.


### 3-8-1 MODBUS RTU Specification

Item	Setting range	Factory default		
Interface	RS-	485		
Maximum transmission distance	100m			
Communication preference setting	Either DIP switches take or software tool takes precedence	DIP switches take precedence		
Parity bit presence	With or without	With		
Parity bit type	Odd / even	Odd		
Stop bit	1 bit / 2 bits	1 bit		
Communication address	1 to 247	1		
Baud rate	9,600 bps 19,200 bps 38,400 bps 57,600 bps 115,200 bps	9,600 bps		

### Settings by DIP switches for RS-485 (all OFF at factory setting)

DIP switches	DIP switches	Setting item	Input status		
DIF SWILCHES	No.		OFF	ON	
→ ON	1	Communication preference setting	DIP switches take precedence	Software tool takes precedence	
	2	Parity bit presence	With	Without	
	3	Parity bit type	Odd	Even	
ω	4	Stop bit	1	2	
4	5	Communication address 1	SW5: OFF, SW6: OFF		
5	5	Communication address 2	SW5: ON,	SW6: OFF	
o 🗌	6	Communication address 3	SW5: OFF, SW6: ON		
7	U	Communication address 4	SW5: ON,	SW6: ON	
0	7	Baud rate	9,600 bps	19,200 bps	
9	8	Unused	-	-	
	9	Unused	-	-	
	10	Unused	-	-	

# 3-8-2 Wiring Example



#### <Reference>

- When the device is used as a terminal station, short-circuit the terminal and E terminal
- Use shielded twisted pair cables.
- The transmission line cables (shielded cables) should be connected in a crossover fashion and grounded at one end.

	Conductor		Insulator		Cable	
Classification	Size	Resistance value (At 20°C)	Material	Thickness (mm)	diameter (mm)	Applicable cable example
Shielded twisted pair	0.5 mm <sup>2</sup> (AWG20) or more	Up to 33.4 Ω/km	Polyethylene	Up to 0.5	Approx. 7.8	Hitachi Cable, Ltd. KPEV-S0.5 mm²×1P Belden Inc. 9207

# 3-8-3 Function Code

# Configuration of communication data

Office No.
Function code
Data
CRC-16

### **Function code**

Function code	Function
0x01	Reading coil (output) status
0x02	Reading relay (input) status
0x03	Reading holding register
0x81	Error in reading coil (output) status
0x82	Error in reading relay (input) status
0x83	Error in reading holding register

# 3-8-4 Error Codes

# Configuration of communication data

Office No.
Function code
Error code
CRC-16

### Error code

Error code	Description
0x01	Function code error
0x02	Address error
0x03	Data quantity error

# **Functions**

# 3-8-5 Address Map

			Bit address	Word address	
	IN1	Safety input 1	0x0000		
IN2 IN3 IN4	IN2	Safety input 2	0x0001		
	IN3	Safety input 3	0x0002		
	Safety input 4	0x0003	0x0000		
lanat	IN5	Safety input 5	0x0004	0.0000	
Input	IN6	Safety input 6	0x0005		
	IN7	Safety input 7	0x0006		
	IN8	Safety input 8	0x0007		
	INT1	Reset input 1	0x0010	00004	
	INT2	Reset input 2	0x0011	0x0001	
	OUT1	O-mtltt-4	0x1000		
	OUT2	Control output 1	0x1001	0.0400	
	OUT3	0 1 1 1 10	0x1002	0x0100	
	OUT4	Control output 2	0x1003	†	
Output	AUX1	Auxiliary output 1	0x1010		
•	AUX2	Auxiliary output 2	0x1011		
	AUX3	Auxiliary output 3	0x1012	0x0101	
	AUX4	Auxiliary output 4	0x1013	1	
	MUTE	Muting indicator output	0x1014		
	IN1/2	Input block 1	_	0x1000	
	IN3/4	Input block 2	_	0x1001	
	IN5/6	Input block 3	_	0x1002	
	IN7/8	Input block 4	_	0x1003	
	LOGIC1	Control block 1	_	0x1100	
	LOGIC2	Control block 2	_	0x1101	
	LOGIC3	Control block 3	_	0x1102	
	ER1	Lockout history (Latest)	_	0x1200	
	ER2	Lockout history (1 save ago)	_	0x1201	
	ER3	Lockout history (2 saves ago)	_	0x1202	
	ER4	Lockout history (3 saves ago)	_	0x1203	
Holding	ER5	Lockout history (4 saves ago)	_	0x1204	
register	LR1	Logic No. history (Latest)	_	0x1300	
	LR2	Logic No. history (1 save ago)	_	0x1301	
	LR3	Logic No. history (2 saves ago)	_	0x1302	
	LR4	Logic No. history (3 saves ago)	_	0x1303	
	LR5	Logic No. history (4 saves ago)	_	0x1304	
	DR1	OFF delay No. history (Latest)	_	0x1400	
	DR2	OFF delay No. history (1 save ago)	_	0x1401	
	DR3	OFF delay No. history (2 saves ago)	_	0x1402	
	DR4	OFF delay No. history (3 saves ago)	_	0x1403	
	DR5	OFF delay No. history (4 saves ago)	_	0x1404	
	RRQ	Reset request status	_	0x2000	
	MUT	Muting condition satisfaction status	_	0x2001	

# 3-8-6 Message Format

# • Function code: 0x01

<Command>

Data	Description	
Office No.	SF-C21 equipment address	
Function code	0x01	
Reading start address (H)	Bit address to read data from	
Reading start address (L)		
Read number (H)	Quantity of data to be read	
Read number (L)	Quantity of data to be read	
CRC-16 (H)	Manager away is demonstrated	
CRC-16 (L)	Message error judgment data	

### <Response during normal operation>

Data	Description	
Office No.	SF-C21 equipment address	
Function code	0x01	
Number of bytes of communication data	Number of bytes of communication data	
Data 1 to be read	Data to be read	
<u>:</u>		
Data n to be read		
CRC-16 (H)	Message error judgment data	
CRC-16 (L)		

# <Response during abnormal operation>

Data	Description	
Office No.	SF-C21 equipment address	
Function code	0x81	
Error code	Error code	
CRC-16 (H)	Manager away indowe and date	
CRC-16 (L)	Message error judgment data	

# 3-8-7 Function Code

### • Function code: 0x02

<Command>

Data	Description	
Office No.	SF-C21 equipment address	
Function code	0x02	
Reading start address (H)	Bit address to read data from	
Reading start address (L)		
Read number (H)	Quantity of data to be road	
Read number (L)	Quantity of data to be read	
CRC-16 (H)	Managa arrar judament data	
CRC-16 (L)	Message error judgment data	

# <Response during normal operation>

Data	Description
Office No.	SF-C21 equipment address
Function code	0x02
Number of bytes of communication data	Number of bytes of communication data
Data 1 to be read	Data to be read
:	
Data n to be read	
CRC-16 (H)	Message error judgment data
CRC-16 (L)	

# <Response during abnormal operation>

Data	Description
Office No.	SF-C21 equipment address
Function code	0x82
Error code	Error code
CRC-16 (H)	Magaga arrar judament data
CRC-16 (L)	Message error judgment data

# • Function code: 0x03 <Command>

Data	Description
Office No.	SF-C21 equipment address
Function code	0x03
Reading start address (H)	Word address to road data from
Reading start address (L)	Word address to read data from
Read number (H)	Quantity of data to be read
Read number (L)	
CRC-16 (H)	Message error judgment data
CRC-16 (L)	

# <Response during normal operation>

Data	Description
Office No.	SF-C21 equipment address
Function code	0x03
Number of bytes of communication data	Number of bytes of communication data
Data 1 to be read (H)	
Data 1 to be read (L)	
:	Data to be read
Data n to be read (H)	
Data n to be read (L)	
CRC-16 (H)	Message error judgment data
CRC-16 (L)	iviessage error juugment uata

## <Response during abnormal operation>

Data	Description
Office No.	SF-C21 equipment address
Function code	0x83
Error code	Error code
CRC-16 (H)	Manage array judgment data
CRC-16 (L)	Message error judgment data

## 3-9 USB Communication

# **⚠** CAUTION

Connections to this device via USB are assumed to include temporary connections for e.g., logic settings and diagnoses.

Constant connections via USB are not allowed.

When this device is connected to PC via a USB cable, various information of this device can be transmitted and received by using the software tool "Configurator SF-C."

For details, refer to "Chapter 5 Software Tool."


## 3-10 Logic Selection Function

## **⚠ WARNING**


For the safety of the overall system and the conformity to the standards applicable in each region or country in which this device is installed, take actions on the customer's own responsibility.


This device incorporates eight preset logics and one customizable logic. The preset logics and customizable logics comply with related international standards.


### <No.1. Total stop control>




### <Timing chart>








### <Timing chart>



Lockout



AUX4

Negative logic of OUT 3 / 4


### [No.3. Sequential muting control]


### <Timing chart>


Auxiliary output

#### · When auto reset is set

AUX2









### <Timing chart>

### Manual reset (standard setting)








### [No.5. Partial stop control 2]

### <Timing chart>


### Manual reset (standard setting)









### <Timing chart>




### [No.7. OR control]




### <Timing chart>





### [No.8. Operation mode selection control]

### <Timing chart>



# 3-11 OFF Delay Time Selection Function

The OFF delay times that this device can set are as follows:

No.	OFF delay time	Stop category
0	0 sec.	0
1	0.1 sec.	
2	0.5 sec.	
3	1 sec.	
4	2 sec.	
5	5 sec.	1
6	10 sec.	
7	15 sec.	
8	30 sec.	
9	60 sec.	

## 3-12 Logic Settings by Software Tool

The software tool is available to change the settings of the following items. When logics are set, control output 1 / 2 maintains OFF status. For details, refer to "Chapter 5 Software Tool."

### <Setting item>

- Input mode
- Logic setting
- Output mode (OFF delay, reset)
- · Auxiliary output mode

### <Detailed setting item>

- Input mismatch allowable time
- ON delay time
- Allowable time difference in muting input
- Muting valid time
- Muting input condition
- Override valid time
- MODBUS (RS-485) communication conditions (Baud rate, parity bit presence, parity bit type, stop bit, and communication address)

Item		Setting range	Factory default
Input mismatch	allowable time	0 (unlimited) to 60 sec. (in units of 0.1 sec.)	1 sec.
ON delay time		0 to 5,940 sec. (in units of 0.1 sec.)	0 sec.
OFF delay time	)	0 to 60 sec. (in units of 0.1 sec.)	0 sec.
Allowable time	difference in muting input	1 to 60 sec. (in units of 1 sec.)	3 sec.
Muting valid tim	ne	0 (unlimited) to 5,940 sec. (in units of 1 sec.)	5,940 sec.
Muting input condition		No priority/A priority/B (D) Priority	No priority
Override valid time		1 to 600 sec. (in units of 1 sec.)	60 sec.
	Baud rate	9,600 bps to 115,200 bps	9,600 bps
RS-485	Parity bit presence	Without / With	With
communication condition	Parity bit type	Odd / even	Odd
	Stop bit	1 bit / 2 bits	1 bit
	Communication address	1 to 247	1

Factory settings of customizable logics are invalid.

## **Functions**

# 3-13 Logic Manual Stop / Start Function

The logics of this device can be stopped and started manually. The logics of this device are stopped according to the procedure below.

- Step 1 Switch the mode selector switch to the "PROG" side.
- Step 2 Press the rotary switch.

The logics of this device are started according to the procedure below.

- Step 1 Switch the mode selector switch to the "RUN" side.
- Step 2 Press the rotary switch.

# 4-1 Types and Settings of Logics

For this device, logic Nos. 0 to 9 and nine types of OFF delay time can be specified. With logic No. 0 specified, the logic is customizable. This device must be connected to a PC to make settings with a software tool.

Logics corresponding to Nos. are shown in the table below.

No.	Logic
0	Customizable logic
1	Overall stop control
2	Parallel muting control
3	Sequential muting control
4	Partial stop control 1
5	Partial stop control 2
6	Two-hand control
7	OR control
8	Operation mode selection control

OFF delay times and stop categories corresponding to Nos. are shown in the table below.

No.	OFF delay time	Stop category
0	0 sec.	0
1	0.1 sec.	
2	0.5 sec.	
3	1 sec.	
4	2 sec.	
5	5 sec.	1
6	10 sec.	
7	15 sec.	
8	30 sec.	
9	60 sec.	

## 4-1-1 Factory Setting

Factory setting of this device is as shown in the table below.

Item	Factory setting
Logic	t .
OFF delay time No.	<b>I</b>
Password 1	00
Password 2	0.0

## 4-2 Preparation for Logic Setting

Preset logic can be set by using this device and power supply only. At the time of setting, devices do not have to be connected to the input section or output section.

Connect power supplies 24V DC and 0V) to the terminal block for internal power supply and the terminal block for external power supply in this device.

If power is supplied to either one of them, this device will not operate.

## 4-2-1 Turning ON the Power

Confirm that the mode selector switch is turned to the "RUN" side (left side: factory setting) and then turn ON the power. The diagnosis function of this device carries out initial diagnosis, turning ON and OFF the indicators one by one.

After the end of initial diagnosis, the operation indicator (green) lights up.

If a terminal block is connected only to the power supply, auxiliary output indicator 1 / 2 / 4 (orange) and interlock indicator 1 / 2 (yellow) light up.


The other indicators turn OFF.

Pressing the rotary switch displays " *[*" (factory setting) in the 7-segment indicator (red), turning ON the logic selection indicator (orange).

## 4-2-2 Portions Used in Settings

The following indicators and switches are used for preset logic settings.

- 7-segment indicator (Red)
- Logic selection indicator (Orange)
- Delay selection indicator (Orange)
- Password selection indicator (Orange)
- Operation indicator (Green)
- Setting indicator (Orange)
- Rotary switch
- Mode selector switch



# 4-3 Operation in RUN Mode and the Display

# 4-3-1 Operation and Display During Normal Operation

Step	Status of indicators and switches	Description
1	CLOG DISE. DISE. DISE. DISE. FROM PROG	Mode selector switch: RUN side Operation indicator (green): Lights up The power saving function of this device turns OFF the 7-segment indicator (red) 3 sec. after power ON, the end of initial diagnosis, or final operation.
2	ODEL OPAS  RUN OPAS  RUN OPAS	Press the rotary switch.  The logic No. currently set is displayed in the 7-segment indicator (red). Logic selection indicator (orange) lights up.  " #: Overall stop control" is set at factory.
3	DLOG DEL PROG	Rotate the rotary switch.  The currently set No. for OFF delay time is displayed in the 7-segment indicator (red). Delay selection indicator (orange) lights up.  " 1: 0 sec." is set at factory.  Rotating the rotary switch returns to No.1.
4	RUN PROG	Logic No. 0 is customizable logic.  To use customizable logic, this device must be connected to a PC to make settings by a software tool.  Refer to "Chapter 5 Software Tool".
5	OLOG OPAS  RUN PROG	Selecting logic No. 0 always displays " - " in the 7-segment indicator (red) as the OFF delay time.


# Operation in RUN Mode and the Display

# 4-3-2 Display When an Error Occurs

Step	Status of indicators and switches	Description
1	OLOG ODEL OPAS RUN PROG	Mode selector switch: RUN side Operation indicator (green): Lights up  During normal operation  The power saving function of this device turns OFF the 7-segment indicator (red) 3 sec. after power ON, the end of initial diagnosis, or final operation.
2	CLOG EZ COMPAS EZ COMPAS EZ COMPAS EZ COMPAS EZ COMPAS EZ COMPAS EX COMPAS COMP	Occurrence of abnormality (Example: internal failure, two inputs short-circuited, etc.) If an error occurs, an error code is displayed in the 7-segment indicator (red), and dots blink.  Either one of error codes " <i>E (</i> " to " <i>E 9</i> " and " <i>E F</i> ." is displayed in the 7-segment indicator (red). For the error codes, refer to "Chapter 7 Troubleshooting".

## 4-4-1 Flowchart of Logic and OFF Delay Time

Logic and OFF delay time are set according to the flow in the figure below.



# 4-4-2 Operation Procedure for Setting Logic and OFF Delay Time

Procedure for setting logic and OFF delay time in this device is described below. To stop setting logic and OFF delay time before Step 23 in the table below, turn the mode selector switch to the "RUN" side, and the settings will be canceled. After Step 24 or later, the settings cannot be canceled.

Step	Status of indicators and switches	Description
1	OLOG ODEL OPAS  RUN PROG  PROG	Mode selector switch: RUN side Operation indicator (green): Lights up The power saving function of this device turns OFF the 7-segment indicator (red) 3 sec. after power ON, the end of initial diagnosis, or final operation.
2	OLOG ODEL OPAS RUN PROG	Switch the mode selector switch to the "PROG" side. This device transitions to "PROG mode."  The operator indicator (green) turns OFF. The setting indicator (orange) blinks.
3	OLOG ODEL OPENS RUN PROG	This device automatically transitions to "Indicator ON confirmation."  Individual segments of the 7-segment indicator (red) light up one by one.  Check for an error code displayed in the 7-segment indicator (red).  Press the rotary switch.
4	OLOG ODEL OPENS RUN PROG	The setting indicator (orange) status changes from blinking to lighting up.  Press the rotary switch.
		Transition to "Enter password."
5	RUN PROG	Password selection indicator (orange) blinks. Password 1 " " " " is displayed in the the 7-segment indicator (red).  Enter password 1 and password 2. At factory, password 1 is set to " " " " ", password 2, " " " ".

Step	Status of indicators and switches	Description
6	CLOS SPEL PROG	Select password. Select a number by rotating the rotary switch.
7	Spel S S S Run PROG Y SPROS	Select password 1 from " [1] " to " [2] ".  Determine password 1 by pressing the rotary switch.
8	PROS PROS	Password 2 "
9	Spel S S S S S S S S S S S S S S S S S S S	Select password 2 from " [1] " to " 9 ".  Determine the password 2 by pressing the rotary switch.  • When password 1 and password 2 are correct, proceed to Step 11.  • When password 1 or 2 is incorrect, proceed to Step 10.
10	COOR EN RUN PROG	"Er" is displayed in the 7-segment indicator (red). Pressing the rotary switch returns to Step 5. Enter the password again.
11	RUN PROG	Transition to "Select setting mode."  Password selection indicator (orange) turns OFF.  The logic selection indicator (orange) and delay selection indicator (orange) blink.  Pressing the rotary switch proceeds to Step 13.

Step	Status of indicators and switches	Description
12	RUN PROG	Rotating the rotary switch blinks the password selection indicator (orange). Rotate the rotary switch further to return to Step 11.
13	OPAS RUN PROG	Transition to "Select operation setting."  The logic No. currently set is displayed in the 7-segment indicator (red). Logic selection indicator (orange) blinks.  " #: Overall stop control" is set at factory.  Rotating the rotary switch proceeds to Step 14.  Pressing the rotary switch proceeds to Step 15.  Holding down the rotary switch proceeds to Step 21.
14	RUN PROG	The currently set No. for OFF delay time is displayed in the 7-segment indicator (red).  Delay selection indicator (orange) blinks.  " 1: 0 sec." is set at factory.  Rotating the rotary switch returns to Step 13.  Pressing the rotary switch proceeds to Step 18.  Holding down the rotary switch proceeds to Step 21.
	1	
15	BERL PROG	Transition to "Set logic."  The logic No. currently set is displayed in the 7-segment indicator (red) and blinks.  Rotate the rotary switch to select Logic No. from " (" to " ").
16	Charles Run Proc	Logic No. 0 is customizable logic. To use customizable logic, this device must be connected to a PC to make settings by a software tool. Refer to "Chapter 5 Software Tool."  If Logic No. 0 is selected, "Set OFF delay time" cannot be selected. OFF delay time for Logic No. 0 is changed with a software tool.

Step	Status of indicators and switches	Description
- 110		As an example, " \( \)" is selected.
17	COPAS - RIAN PROG	Press the rotary switch for the determination and return to Step 13. Holding down the rotary switch determines the selection and then returns to Step 21.
18	Run Proc	Transition to "Set OFF delay time."  The current No. for OFF delay time is displayed in the 7-segment indicator (red) and blinks.
19	DOG PRIN PROG	Rotate the rotary switch to select OFF delay time from " " to " ".
20	RUN PROG	As an example, " []" is selected.  Press the rotary switch for the determination and return to Step 14.  Holding down the rotary switch determines the selection and then returns to Step 21.
21	PAS RUN PROG	Transition to "Confirm operation setting."  Logic No. is displayed in the the 7-segment indicator (red).  Rotate the rotary switch.


Step	Status of indicators and switches	Description
		The No. for OFF delay time is displayed in the 7-segment indicator (red).
22	OLOG DEL PROG	When the selected logic and OFF delay time are confirmed, hold down the rotary switch to proceed to Step 24.     If either or both of the logic or OFF delay time differ from those selected, rotate the rotary switch.
23	BLOG BY SIN PROG	In the 7-segment indicator (red), " <b>b p</b> " indicating "Back" is displayed. The logic selection indicator (orange) and delay selection indicator (orange) light up.  Pressing the rotary switch returns to Step 13. Select logic and OFF delay time again.
		Holding down the rotary switch changes the display to that shown in the il-
24	RUN PROS	In the 7-segment indicator (red), "   **P" indicating "OK" is displayed.  The logic selection indicator (orange) and delay selection indicator (orange) blink.  Transition to "Write / confirm operation setting."  The logic and OFF delay time set in this device have been changed.  Releasing the hand from the rotary switch proceeds to the next step.
		After the end of write operation, logic No. and No. for OFF delay time are
25	DOR NUN PROG	alternately displayed in the 7-segment indicator (red).  A logic No. is shown in the illustration at left.  Logic selection indicator (orange) lights up.  As an example, " { " is selected.
		No. for OFF delay time is shown in the illustration at left.
26	ODE RUN PROC	Delay selection indicator (orange) lights up.  As an example, " []" is selected.  After confirming operation setting, press the rotary switch.
27	OLOG ODEL OPEN PROS PROS	Transition to "Quit setting mode."

Step	Status of indicators and switches	Description
28	OLOG ODEL OPAS RUN PROG	Switch the mode selector switch to the "RUN" side.  The operation indicator (green) blinks.  Press the rotary switch.
29	OLOG ODEL OPAS RUN PROG	The operation indicator (green) status changes to lighting up.  This device transitions to "RUN" status.

# 4-5 Change Password


## 4-5-1 Flowchart of Change Password

Password is changed according to the flowchart below.



## 4-5-2 Operation Procedure for Change Password

The procedure for changing the password (password 1 / 2) set in this device is described below. To stop changing the password before Step 19 in the table below, turn the mode selector switch to the "RUN" side, and the operation for change password will be canceled. After Step 20 or later, the operation cannot be canceled.



# **Change Password**

Step	Status of indicators and switches	Description
6	RUN PROG	Select password 1. Select a number by rotating the rotary switch.
7	Spei SS S S S S S S S S S S S S S S S S S	Select password 1 from " 🗓 " to " 🖢 ".  Determine password 1 by pressing the rotary switch.
8	RUN PROG	Password 2 "
9	CLOS G G G G G G G G G G G G G G G G G G G	Select password 2 from " III" to " II".  Determine password 2 by pressing the rotary switch.  When password 1 and password 2 are correct, proceed to Step 11.  When password 1 or 2 is incorrect, proceed to Step 10.
10	Er Proc Proc Proc Proc Proc Proc Proc Pro	" <b>E</b> r " is displayed in the 7-segment indicator (red).  Pressing the rotary switch returns to Step 5.  Enter the password again.
11	RUN PROG	Transition to "Select setting mode."  Password selection indicator (orange) turns OFF.  The logic selection indicator (orange) and delay selection indicator (orange) blink.

Step	Status of indicators and switches	Description
этор	Claractoria and Switchics	Rotating the rotary switch blinks the password selection indicator (orange).
12	CLOG GDER	Press the rotary switch.
13	PROG PROG	Transition to "Set password."  Password 1 " " " " is displayed in the the 7-segment indicator (red).
14	RUN PROG	Set password 1. Select a number by rotating the rotary switch. Select password 1 from " " " " " to " " " " ". As an example, select " " for password 1 and then determine it by pressing the rotary switch.
15	RUN PROG	Password 2 " 🗓 🗓 " is displayed in the the 7-segment indicator (red).  Set password 2.  Similarly, select a number by rotating the rotary switch.
16	SLOG SPEL SPECIAL SPEC	Select password 2 from "


Step	Status of indicators and switches	Description
17	CLOG DEEL PROG	Transition to "Confirm password." Display password 1. Rotate the rotary switch.
18	CLOG CODEL CODE CODE CODE CODE CODE CODE CODE CODE	Display password 2.  When the selected password is correct, hold down the rotary switch to proceed to Step 20.  If the selected password is incorrect, rotate the rotary switch.
19	CLOG DEL PIO PROG	In the 7-segment indicator (red), " <b>b y</b> " indicating "Back" is displayed.  Pressing the rotary switch returns to Step 13.  Set passwords 1 and 2 again.
20	SLOG P SPECIAL PROGENIA SPECIAL SPECIA	Holding down the rotary switch changes the display to that shown in the illustration at left. In the 7-segment indicator (red), "
21	OLOG DEL PROG PROG PROG PROG	After the end of write operation, password 1 and password 2 are alternately displayed in the 7-segment indicator (red).  Password 1 is shown in the illustration at left.  As an example, " [] [ ] " is shown.
22	CLOG GODEL G	Password 2 is shown in the illustration at left.  As an example, " <b>g g</b> " is shown.  After confirming password 1 and password 2, press the rotary switch.

Step	Status of indicators and switches	Description
23	OLOG ODEL OPAS RUN PROG	Transition to "Quit setting mode."
24	OLOG ODEL OPAS RUN PROG	Switch the mode selector switch to the "RUN" side.  The operation indicator (green) blinks.  Press the rotary switch.
25	CLOG CDEL CPAS  RUN PROG  PROG	The operation indicator (green) status changes to lighting up.  This device transitions to "RUN" status.

## **CAUTION**

Connections to this device via USB are assumed to include temporary connections for e.g., settings and diagnoses. Constant connections via USB are not allowed.

## 5-1 System Configuration



### 1. Software tool "Configurator SF-C"

Exclusive for this device.

It is used for logic settings, diagnoses, and preparation of documents.

The software tool is downloadable at our website.


URL: http://www3.panasonic.biz/ac/j/dl\_center/software/index.jsp?c=search

In addition to "Narrow down by Part No. / Model No. format", use "SF-C21" for searching.

#### 2. USB cable

Use a USB cable available in the market.

Type of cable	Length
USB 2.0 cable (A: miniB)	3m or less







(On the side of PC)

USB A type (male) - USB miniB type (5 pin, male)

On the side of this device

## 5-2 Required System Specifications

Operation of the software tool "Configurator SF-C" requires the following environment. Confirm that the system in use satisfies the conditions and all the devices required have been prepared.

### 5-2-1 Operating System

Microsoft Windows Vista (32 bit / 64 bit). Windows 7 (32 bit / 64 bit)
The user to be logged in must be specified as "Administrator" or "Power User".

### 5-2-2 PC Specifications

Hardware specifications recommended by Windows. Fixed disk: Free space of 200 MB or more USB port

### 5-3 Installation

Double-click downloaded "ConfiguratorSF-C v\*\*\*".

Install the program according to the instruction of the installation program.

This installation program requires two installations: installation of software tool and installation of USB driver for this device.

If a warning message for Windows, e.g., "User account control" or "Publisher of the driver software cannot be verified", may be displayed before the completion of installation, such a message does not cause any problem. Proceed to the next step.

Installing the USB driver is completed automatically when this device is connected to the PC.

### 5-4 Uninstallation

Uninstall the following 2 items:

Step 1 Configurator SF-C


Step 2 Windows Driver Package - SF-C20(usbser) Ports(11/15/2007 \*\*)

Select "Start" → "Control Panel" → "Program and Features", and then uninstall them.

### 5-5 Connection of this Device and a PC

### 5-5-1 Connection to "Monitor Mode"

To recognize this device by connecting it to a PC, perform the following procedure:



The procedure above is enabled either before or after the activation of the software tool that is described in the next section.

# 5-5-2 Connection to "Transfer Mode"

Step	Status of indicators and switches	Description
1	CLOG COEL COEL COEL COEL COEL COEL COEL COEL	When this device is put in "Monitor mode," turn the mode selector switch to the "PROG" side.  The operation indicator (green) turns OFF. The setting indicator (orange) blinks.
2	DLOG ODEL OPAS RUN PROG	This device automatically transitions to "Indicator ON confirmation."  Individual segments of the 7-segment indicator (red) light up one by one.  Check for an error code displayed in the 7-segment indicator (red).  Press the rotary switch.
3	CLOG COCK COCK COCK COCK COCK COCK COCK CO	The device enters "Transfer mode."  "Transfer mode" disables setting operation on the side of this device. The software tool is used, for example, to transfer customizable logic to this device and change password.  "Transfer mode" puts all control outputs in OFF status.

# Step | Status of indicators and switches Description When this device is put in "Transfer mode," turn the mode selector switch to the "RUN" side. The operation indicator (green) blinks. 1 Press the rotary switch. "[" is displayed in the 7-segment indicator (red). All the other indicators turn OFF. Press the rotary switch. 2 The device enters "Monitor mode." The operation indicator (green) lights up. In "Monitor mode." the software tool is used to read data from and monitor 3 "Monitor mode" prevents writing data into this device. When writing data into this device again, refer to Procedure "5-5-2 Connection to "Transfer Mode".

## 5-5-3 Setting to "Monitor Mode" after the End of Transfer

### 5-5-4 Disconnection of this Device from a PC

When the USB cable is unplugged from this device, it can be disconnected from the PC. The USB cable can be unplugged except when "logic is being transferred" by the software tool. When the mode selector switch is turned to the "RUN" side after the USB cable is unplugged, pressing the rotary switch has this device perform normal operation.

### 5-5-5 Initialization of this Device


Unplugging the USB cable during writing operation displays " **£ 1** " in the 7-segment indicator (red), putting it in the lockout status. When " **£ 1** " is displayed, connect this device to the PC again and initialize it by referring to "**5-21-1-2 Initialize Settings**".

# 5-6 Startup and End of Software Tool

## 5-6-1 Startup Software Tool

Startup the software tool "Configurator SF-C" according to the procedure below.

- Step 1 Click the "Start" button in Windows.
- Step 2 From All Programs, go to "Panasonic-ID SUNX Safety" and "Configurator SF-C" in order, and then select Configurator SF-C.
- Step 3 Starting up the software tool "Configurator SF-C" displays the main menu and selection menu.




From the selection menu, select one of the following four operations:

- Create a new file
- Open sample logic
- Open a recent file
- Upload logic from device

## Startup and End of Software Tool

#### ■ To Create a new file


Pressing "Create a new file" has the selection menu disappear, making the main screen clear. Free logics can be created.



### ■ To Open sample logic


Pressing "Open sample logic" displays the "Open sample logic" screen. Eight preset logics provided to this device can be used as sample logics.

Select one from preset logics No.1 to No.8. Sample logics are revised to create logics.



#### ■ To Open files saved

Pressing "Open a recent file" displays the "Open file" screen. Select a file to be opened.



■ To obtain a logic from this device in connection

Pressing "**Upload logic from device**" starts communication with this device, acquiring a logic.




# 5-6-2 End of Software Tool

To exit the software tool, follow one of the methods below.

# <Method 1>

From the menu bar, select "File (F)" and then "Close (X)".



### <Method 2>

Click at the upper right corner of the screen.


# 5-7 New / Save / Print of a File

# 5-7-1 Create New File

New files are created by using one of the following methods.


### <Method 1>

When the software tool starts up, select "Create a new file".



# <Method 2>


From the menu bar, select "File (F)" and then "New (N)".



# <Method 3>

Click "New" icon on the toolbar.






When a new file is created according to one of the methods, the main screen is made clear.

# 5-7-2 Open Sample Logic

Open sample logic is performed according to one of the following methods.

# <Method 1>

When the software tool starts up, select "Open sample logic".



# <Method 2>

From the menu bar, select "File (F)" and then "Open sample logic (L)".




# <Method 3>


Click the "Open sample logic" icon on the toolbar.



When "Open sample logic" is displayed, select a logic with the "Previous" and "Next" button, and then press "OK".



The logic is displayed in the main screen.




# 5-7-3 Open a Recent File

Existing files are opened by using one of the following methods.


# <Method 1>

When the software tool starts up, select "Open a recent file".



# <Method 2>


From the menu bar, select "File (F)" and then "Open (O)".



### <Method 3>


Click "Open" icon on the toolbar.





When the file selection diagram is displayed, select a file and click "Open (O)".

Opening the file displays a logic in the main screen.




# 5-7-4 Upload Logic from this Device

To obtain logics from this device, one of the following methods is performed.

Connect this device with a PC according to procedure "5-5-1 Connection to "Monitor Mode"".

# <Method 1>

When the software tool starts up, select "Upload logic from device".



### <Method 2>

From the menu bar, select "Device (D)" and then "Upload logic from device (U)".



### <Method 3>

Click the "Upload logic from device" icon on the toolbar.



# 5-7-5 Saving a File

Save a logic, to be displayed in the main screen, in the PC as a file. The file format of the files to be created is specified to be file name ".sfc".

Select "Save" to save a file to the same file, and select "Save as" to save under a new file name.

### ■ Save

Files are saved by one of the following methods:

# <Method 1>

From the menu bar, select "File (F)" and then "Save (S)".



### <Method 2>

Click the "Save" icon on the toolbar.




### ■ Save as

Files are saved under new file names by one of the following methods:

### <Method 1>

From the menu bar, select "File (F)" and then "Save as (A)".




### <Method 2>

Click the "Save as" icon on the toolbar.



Specify a place to save the file and the file name, and click "Save (S)".



# 5-7-6 Download Logic to Device


Logic is transferred to this device according to the following procedure:

Connect this device to the PC according to the procedures "5-5-1 Connection to "Monitor Mode" and "5-5-2 Connection to "Transfer Mode".

### Step 1

### <Method 1>

From the menu bar, select "Device (D)" and then "Download logic to device (D)".




### <Method 2>

Click the "**Download logic from device**" icon on the toolbar.



# Step 2 Diagnosing logic

Diagnose the logic created. This shows a display without error. Click "**OK**" and proceed to the next step.



This shows a display with some error in the logic created.

Click "**OK**" to return to the main screen, and then correct the logic.

The place of an error is highlighted in a red frame in the main screen.



# Step 3 Completion of entry and transfer of password

Enter the password and click "OK".

Logic is being transferred.


While being transferred, do not remove the USB cable, or do not turn OFF the power supply.

The file has been downloaded. Click "**OK**".

According to the procedures "5-5-3 Setting to "Monitor Mode" after the End of Transfer" and "5-5-4 Disconnection of this Device from a PC", return this device to the monitor mode and remove the USB cable.








# 5-7-7 Print

Logic is printed by one of the following methods:

# <Method 1>

From the menu bar, select "File (F)" and then "Print (P)".




File  $(\underline{F})$  Device $(\underline{D})$  Help  $(\underline{H})$ 


### <Method 2>

Click the "Print" icon on the toolbar.

When the print dialog is displayed, select a printer and perform printing.




Preview is displayed on the backside of the dialog box. The contents can be confirmed before printing.



# 5-8 Each Part Name of the Software Tool and Basic Operation

The main screen of the software tool is comprised of the following elements:



### ■ Menu bar

All the operations and functions of the software tool are prepared in a menu format according to various applications.

# ■ Toolbar

Frequently used functions are displayed with icons.



File(F) Device(D) Help (H)

### ■ Input block

Input devices are selected, and input mismatch time, etc., are set.

Clicking the input block opens "Input select".



### ■ Connection tab

Clicking this tab connects a circuit.



### ■ Output block

ON delay time and OFF delay time for control output are set.



### **■** Control block 1


Required control is selected from from AND, OR, parallel muting control, sequential muting control, two-hand control, and input select.

Selecting parallel muting control or sequential muting control activates detailed settings, allowing required detailed items to be set in muting.



### ■ Control block 2 / 3

Required logic is selected from AND, OR and no logic.



### ■ Interlock block

Overall reset, partial reset (manual start) and partial reset (auto start) are carried out.



# ■ Auxiliary output block

Settings of auxiliary output can be changed. The results of the monitoring of input devices, internal logic, etc., are set as auxiliary output.



# ■ Mode switching block

Switching is performed between edit mode and simulation mode.



# 5-9 Creating and Editing a Logic, and Saving a File and Transferring it to this Device

# 5-9-1 Creating and Editing Logic

The following methods are available to create and edit logic.

### ■ Creating a new logic

A logic is created according to "5-7-1 Create New File".

# ■ Open and edit a logic according to Open sample logic

Sample logic is opened and edited according to "5-7-2 Open Sample Logic". When a logic uses "Parallel muting," "Sequential muting," "Two-hand control," and "Input select,"

editing an applicable logic by opening it is easier than by creating a new logic.

# ■ Open a recent file and edit it

When a logic has already been created, open a recent file and edit it according to "5-7-3 Open a Recent File".

# Obtain a logic from this device and edit it

According to "5-7-4 Upload Logic from this Device", obtain the logic, which is being used in this device, and edit it.

# 5-9-2 Saving a Logic File and Transferring it to this Device

# ■ Saving a logic in the PC

After a logic is created and edited, it is saved in the PC as a file according to "5-7-5 Saving a File".

# ■ Transfer a logic to this device

After a logic is created and edited, it is transferred to this device according to "5-7-6 Download Logic to Device".

# 5-10 Create a Logic

# 5-10-1 Create a Logic


As an example, sample logic No.1 is created from the new screen.

# 5-10-1-1 Set Input Lock

Click input block 1 and open "Input select". Click "**2NC**" at the upper left portion.



Selected "2NC" is set in input block 1.




Similarly set input blocks 2, 3 and 4. Set all input blocks to "2NC".



# 5-10-1-2 Set Control Block 1

Click control block 1 and open "Select control". Click "**AND**" at the upper left portion.



Selected "AND" is set in control block 1.




# 5-10-1-3 Create a Circuit


Click "A" of connection tab 1 to connect it to A of input block 1.



Similarly click "**B**" of connection tab 1 to connect it to B of input block 2. Click "**C**" to connect it to C of input block 3. Click "**D**" to connect it to D of input block 4.




Click "E" of connection tab 4 to connect it to E of connection tab 1.



Click "E" of connection tab 5 to connect it to E of connection tab 1.

Sample logic No.1 is created completely.



# 5-10-2 Example of a Logic Using Control Block 1 / 2

Click control block 2 and open "Select control". Click "AND".




Selected "AND" is set in control block 2.



- Click "C" of connection tab 1 to connect it to C of input block 3. Click "D" to connect it to D of input block 4.
- Click "A" of connection tab 2 to connect it to A of input block 1. Click "B" to connect it to B of input block 2.
- Click "F" of connection tab 4 to connect it to F of connection tab 2.
- Click "E" of connection tab 5 to connect it to E of connection tab 1.

The following logic is created.


- Output block 1 outputs the AND of input blocks 1 and 2.
- Output block 2 outputs the AND of input blocks 3 and 4.




# 5-10-3 Example of a Logic Using Control Block 1 / 2 / 3

For the creation of a logic of control block 1/2, refer to "5-10-2 Example of a Logic Using Control Block 1 / 2".

Click control block 3 and open "Select control". Click "AND".



Selected "AND" is set in control block 3.




Click the following portions to perform wiring.

- Click "E" of connection tab 3 to connect it to E of connection tab 1. Click "F" to connect it to F of connection tab 2.
- Click "G" of connection tab 4 to connect it to G of connection tab 3.
- Click "E" of connection tab 5 to connect it to E of connection tab 1.

The following logic is created.

- Output block 1 outputs the AND of control blocks 1 and 2.
- Output block 2 outputs the AND of input blocks 3 and 4.



# 5-11 Select Input

# 5-11-1 Types of Inputs

### ■ 2NC

Used to connect the safety device of 2NC contact output.

### ■ 1NO / 1NC

Used to connect safety device of 1NO / 1NC contact output.

# ■ PNP×2 (equ.)

Used to connect safety devices (PNP semiconductor output × 2). The safety device to be used is a type that turns "ON-OFF" two outputs simultaneously.



# ■ Muting input (equ.)

Used as an input of mute sensor when it is selected as "Parallel muting" or "Sequential muting" in control block 1.

This connects a mute sensor having 2NC contact or outputs [PNP semiconductor output × 2 (equ.)].

When "Sequential muting" is set in control block 1, both "Muting input (equ.)" and "Muting input (dif.)" cannot be used at a time.

# ■ Muting input (dif.)

Used as the input of mute sensor when it is selected as "Parallel muting" or "Sequential muting" in control block 1.

This connects a mute sensor having 1NO / 1NC contact or outputs [PNP semiconductor output × 2 (dif.)].

When "Sequential muting" is set in control block 1, both "Muting input (equ.)" and "Muting input (dif.)" cannot be used at a time.

### ■ Override

Used as the input of override switch when it is selected as "Parallel muting" or "Sequential muting" in control block 1.

Connects a momentary type switch for 1NO / 1NC contact.

### ■ Key selector

Used as the input of key selector switch when "Input select" is selected in control block 1. Connects an alternate type key switch (with a forced breaking contact) for 1NO / 1NC.

### ■ Test

When test input is effective, the control output is turned into OFF status.

The switch for 1NC contact or PNP semiconductor output (normally set to ON) is connected.

- Contact "Close" or output ON: Test input invalid
- Contact "Open" or output OFF: Test input valid

The input block with this input selected is not connected to connection tab, control block, or output block. If connected, the input block is judged to be erroneous by the software tool.

### ■ 1NC

Used to connect the safety device of 1NC contact output. In this case, the category of the system including this device is specified to be category 2 or less.

# ■ PNP×2 (dif.)

Used to connect safety devices (PNP semiconductor output × 2). The safety device to be used is a type that turns "ON-OFF" two outputs alternately.

### ■ PNP×1

Used to connect a safety device (PNP semiconductor output × 1). In this case, the category of the system including this device is specified to be category 2 or less.

# ■ No logic

If the number of safety devices in connection is less than 4, they are used for unused input block. If a safety device is connected, the operation is not reflected.


### <Reference>

For the connectable input blocks, and combinations of them with control blocks, refer to "5-19 Configuration Check".

# 5-11-2 Setting of Contact Input Mismatch Allowable Time

Setting "2NC" or "1NO / 1NC" in the input block displays a small blue window. Mismatch allowable time is set between two inputs by using up-down arrows in the input block or by direct entry.

	Settable range	Initial setting
Input mismatch allowable time	0 (unlimited) to 60 sec. (in units of 0.1 sec.)	1 sec.



# 5-12 Select Control

Selectable control in control block 1 / 2 / 3

### AND

"AND" of inputs connected to the control block is output.

Two or more inputs are connected.

The input blocks in which muting input (equ.), muting input (dif.), override, key selector or test has been set cannot be connected.

### OR

"OR" of inputs connected to the control block is output.



# ■ No logic

Selected when the control block is unused.



Selectable control only in control block 1

# ■ Parallel muting

Used when "Parallel muting" is performed.

# ■ Sequential muting

Used when "Sequential muting" is performed.

When "Sequential muting" is selected, both "Muting input (equ.)" and "Muting input (dif.)" cannot be used for input block at a time.

### ■ Two-hand control

Used to configure Two-hand control devices of ISO 13851 (JIS B9712).

### ■ Select input

When output, state is switched between the two input blocks.

Three input blocks are connected to control blocks, and one of them is specified to be "key selector".

### <Reference>

For the connectable input blocks, and combinations of them with control blocks, refer to "5-19 Configuration Check".

# 5-13 Interlock block

Reset operation of this device is set.

Click and select the interlock block.

The combinations of overall resets and partial resets are unavailable.

- Overall reset
- Partial reset (auto start) + Partial reset (auto start)
- Partial reset (auto start) + Partial reset (manual start)
- Partial reset (manual start) + Partial reset (auto start)
- Partial reset (manual start) + Partial reset (manual start)



### ■ Overall reset

The outputs of two systems of this device are reset by one operation.

- Manual reset : Momentary type switch is connected to between INT11 and INT12.
  - Switching the switch contact from "Closed to Open" performs reset operation.
- Auto reset : Short-circuit is generated between INT21 and INT22.

If INT21-INT22 is not short-circuited when power is turned ON, manual reset is automatically selected.

### ■ Partial reset

Each of the outputs of two systems of this device is reset individually.

- Manual reset: Momentary type switch is connected to between INT11 and INT12 and between INT21 and INT22. Switching the switch contact from "Closed to Open" performs reset operation.
- Auto reset : Short-circuit is generated between INT11 and INT12 and between INT21 and INT22.

Also refer to "3-4 Interlock (Reset)".

# 5-14 Auxiliary Output Block


Operations of four auxiliary outputs of this device are set.

Click and select the auxiliary output block.

"Muting indicator output: MUTE" cannot be changed.

### Initial settings are as follows:

AUX1	negative logic output of OUT1 / OUT2
AUX2	Negative logic of OUT3 / OUT4
AUX3	Reset trigger output
AUX4	Lockout output
MUTE	Muting indicator output (fixed)



The following operations can be set in auxiliary outputs.

- Positive logic output or negative logic output of OUT1 / OUT2
- Positive logic output or negative logic output of OUT3 / OUT4
- Output A / B / C / D of diagnosis results of input block 1 / 2 / 3 / 4
- Output E / F / G of diagnosis results of internal logical circuit
- Reset trigger output
- Lockout output
- Muting indicator output
- Monitor output of IN1 to 8
- Normally off

Also refer to "3-3 Auxiliary Output".



# 5-15 Mode switching block

# 5-15-1 Mode Switching

Clicking the mode switching block can switch between "Edit mode" and "Simulation mode."

# 5-15-2 Simulation Mode

Click "Simulation mode" of the motor switching block.

Logic is diagnosed before transition to Simulation mode.

If an error exists, the message at right is displayed.


Pressing "**OK**" returns to edit mode in the main screen, highlighting the control block and connection tab in red frames.

If no error exists, the message at right is displayed.

Pressing "**OK**" transitions to simulation mode in the main screen.








Transition to simulation mode has been performed.


As an example, sample logic No.1 is used.

In simulation mode, it operates as auto reset regardless of the setting of interlock.




# **Mode Switching Block**


Click "•" of IN1 of input block 1. It turns light color.
This indicates that the contact is "closed."




In all input blocks, click "■".
In OUT1 to OUT4, "■" turns light color.
This indicates that the output is in ON status.



Click "**Edit mode**" of the mode switching block to terminate simulation mode.







# 5-16 Output Setting, OFF Delay and ON Delay Setting

OFF delay time and ON delay time for control output are set.

OFF delay time and ON delay time can be set by using up-down arrows of the output block or by direct entry.

	100
	_
-	No.
	-
	200

	Setting range	Initial setting
OFF delay time	0 to 60 sec. (In units of 0.1 sec.)	0 sec.
ON delay time	0 to 5,940 sec (In units of 0.1 sec.)	0 sec.

# 5-17 Detailed Settings (Muting)

"Detailed Settings" is active by setting "Parallel muting" or "Sequential muting" in control block 1. Clicking "**Details**" opens "Detailed settings."

"Time difference between sensor inputs," "Duration," and "Input priority" for muting and "Duration" for override are set.

	Setting range	Initial setting
Muting input allowable time difference	1 to 10 sec.	3 sec.
Muting duration	0 (Unlimited) to 5,940 sec. (In units of 1 sec.)	5,940 sec.
Muting input condition	No priority / A priority / B (D) priority	No priority
Override duration	1 to 600 sec. (In units of 1 sec.)	60 sec.



# 5-18 Verify Files on the Device and PC

Logic created in the main screen is compared with the customizable logic of this device. If a difference exists, the target input block, control block and connection tab are highlighted in white frames.



# 5-19 Configuration Check

A logic created in the main screen is checked. If an error exists on a dangerous side, the target input block, control block and connection tab are highlighted in red frames. Only the faults that lead to danger are determined as errors.

# Combinations of input blocks and control block 1

<b>•</b> :	Mandatory	Control block 1						
0:	Connectable Not connectable	AND OR P-MUTE		S-MUTE	Two-hand operation control	Select input		
	Number of input connections	2 to 4	2 to 4	2 or 3	3 or 4	2	3	
	2NC	0	0	×	×	0	0	
	1NO/1NC	0	0	×	×	0	0	
	PNP×2 (equ.)	0	0	●Note 1	●Note 1	0	0	
쏭	PNP×2 (dif.)	0	0	● Note 1	Note 1	0	0	
	Muting input (equ.)	×	×	Note 2	Note 3	×	X	
block	Muting input (dif.)	×	×	Note 2	Note 3	×	X	
Input	Override	×	×	0	0	×	X	
ᆸ	Key selector	×	×	×	×	×	•	
	PNP×1	0	0	×	×	×	0	
	1NC	0	0	×	×	×	0	
	Test	×	×	×	×	×	×	
	No logic	0	0	×	×	×	×	

Notes: 1) For either PNP×2 (equ.) or PNP×2 (dif.), only one connection is allowed.

# Combinations of input blocks and control block 2 / 3, and connection tab E / F

O: Connectable		Control	block 2	Control block 3	
×:	Not connectable	AND	OR	AND	OR
Number of input connections		2 to 4	2 to 4	2 to 4	2 to 4
	2NC	0	0	0	0
	1NO/1NC	0	0	0	0
	PNP×2 (equ.)	0	0	0	0
	PNP×2 (dif.)	0	0	0	0
송	Muting input (equ.)	×	×	×	×
block	Muting input (dif.)	×	×	×	×
Input	Override	×	×	×	×
ם	Key selector	×	×	×	×
	PNP×1	0	0	0	0
	1NC	0	0	0	0
	Test	×	×	×	×
	No logic	0	0	×	×
	Connection tab E	0	0	0	0
	Connection tab F	×	×	0	0

<sup>2)</sup> For either Muting input (equ.) or Muting input (dif.), only one connection is allowed.

<sup>3)</sup> For either Muting input (equ.) or Muting input (dif.), two connections are allowed.

# 5-20 Highlighting OFF

Highlighting by "5-18 Verify Files on the Device and PC" or "5-19 Configuration Check" is off.



# 5-21 Device Information

For this device.

- Change password,
- Initialization of settings,
- · Configuration log check, and
- Error log

can be performed.

From the menu bar, select "Device (D)" and then "Device information (I)".

# Device Information( $\underline{I}$ )... Communication Settings( $\underline{C}$ )... Upload logic from device( $\underline{U}$ ) Download logic to device( $\underline{D}$ ) Monitor( $\underline{M}$ )...

### 5-21-1 General

Clicking "General" tab displays device name, device Ver., serial No. and current logic No. Password change and initialization of settings can be performed.




# 5-21-1-1 Change Password

Clicking "Change password" displays "Change password."

After the password is entered, clicking "**OK**" changes the password to new one.

If the password is wrong, the message "The password is not correct." displayed. In response to it, enter the correct password again.



### 5-21-1-2 Initialize Settings


To return settings of this device to the factory settings or when error No. " **£ !!** " is displayed, initialize this device according to the following procedure. The passwords (Password 1 " **!! !!** " and Password 2 " **!! !!** ") are also initialized.

- Step 1 Connect this device in "Write mode" according to "5-5-1 Connection to "Monitor Mode" or "5-5-2 Connection to "Transfer Mode".
- Step 2 From the menu bar, select "Device (D)" and then "Device information (I)" to open "Device information."
- Step 3 Click the General tab "Initialize Settings".
- Step 4 When "Confirm password" opens, enter the password.
- Step 5 Clicking "OK" performs initialization.


# 5-21-2 Configuration Log

Clicking "Configuration log" confirms logics transferred.

Five pieces information, including the latest one, can be confirmed.




Clicking the bar of a log to be confirmed opens a different screen, allowing you to confirm the logic.



# 5-21-3 Error Log

Clicking "Error log" confirms logs of errors that occurred in the past.

The past 5 logs can be confirmed.




# 5-22 Communication Settings

The communication settings of this device are made.


From the menu bar,

select "Device (D)" and then "Communication settings (C)".



Baud rate, parity bit, stop bit, and addresses can be set.

For details on communication settings, refer to "3-8 MODBUS Communication (Non-safety)".




# 5-23 Monitor

The current status of this device can be monitored.

The monitoring operation is performed by one of the following methods:

# <Method 1>

From the menu bar, select "File (F)" and then "Monitor (M)".




# <Method 2>

Click the "Monitor" icon on the toolbar.



The monitor screen opens.



# 5-24 Help

In Help menu,

- Language setting of software tool (Japanese / English),
- Display of manual, and
- Confirmation of version of the software tool can be performed.

# 5-24-1 Language

From the menu bar, select "Help (H)" and then select "Language (L)".

Select a language in which the software tool is displayed.



If the language is changed, the software must be restarted. The logic, which is being used for operation and has not yet been saved, should be saved according to the dialog.

### 5-24-2 Manual


From the menu bar, select "Help (H)" and then select "User Manual (M)".

The manual written in the language currently selected is displayed.



### 5-24-3 Version Information

From the menu bar, select "Help (H)" and then select "Version (V)".



Version information of the software tool is displayed.



# **Chapter 6 Maintenance**

### <Reference>

In the event of an error, refer to "Chapter 7 Troubleshooting" and notify the authorized engineer of the contents.

If the problem cannot be resolved internally, contact our office.

Please make a copy of this checklist, check each inspection item in the respective square, and file the list for record.

# 6-1 Daily Inspection

# **⚠ WARNING**

Be sure to confirm that the following items prior to operation and confirm that there is no error. Operating this device without inspection or in an error condition can result in death or serious injury.

### Inspection item table (daily inspection)

Check column	Inspection item	
	There is no defect, fold, or damage in the wiring.	
	The terminal blocks are free from dirt or foreign matter deposited on them.	
	The corresponding connectors have been connected securely.	
	The unit is securely installed to the DIN rail or securely mounted by means of machine screws.	

# 6-2 Periodic Inspection (Every Six Months)

# **⚠ WARNING**

Be sure to inspect the following items every six months and confirm that there is no error. Operating this device without inspection or in an error condition can result in death or serious injury.

# Inspection item table (periodical inspection)

Check column	Inspection item
	The structure of the machine does not obstruct any safety mechanism for stopping operation.
	No modification has been made in the machine controls which obstructs the safety mechanisms.
	The output of this device is correctly detected.
	The wiring from this device is correct.
	The actual number of operation cycle (time) of the limited lifetime parts (relay, etc.) is less than their rated operation cycles (time).
	No screws or connectors of this device are loose.

### 6-3 Inspection after Maintenance of this Device

Check all of the inspection items given in "6-1 Daily Inspection" and "6-2 Periodic Inspection (Every Six Months)" when the status of this device is as described below.

- 1) When changes are made to the settings of the device.
- 2) When any parts of this device are replaced.
- 3) When some abnormality is felt during operation.
- 4) When the device installation place or environment is changed.
- 5) When the wiring method or wiring layout is changed.
- 6) When a component or components of a FSD (Final Switching Device) to which the control output is connected are replaced.
- 7) When FSD (Final Switching Device) setting is changed.

# **Chapter 7 Troubleshooting**

#### <Reference>

- Check the wiring.
- Check the power supply voltage and the power supply capacity.

#### <All indicators are OFF>

Cause	Remedy
Power is not being supplied.	Check that the power supply capacity is sufficient. Connect the power supply correctly.
Supply voltage is out of the specified range.	Set the supply voltage correctly.
Connector is not connected securely.	Connect the connector securely.

### <Input indicator (orange) 1 to 8 blinks>

Cause	Remedy
The time for which the safety input is ON exceeds the input mismatch allowable time.	Turn OFF the blinking input block once and turn it ON within the input mismatch allowable time.
Wiring connecting safety contact or safety sensor is disconnected while safety input is ON. (One of duplex inputs is turned OFF.)	Recheck the wiring of the safety inputs, turn OFF the blinking input block, and then turn it ON.

### <Interlock indicator (yellow) 1 / 2 lights up>

Cause		Remedy
Reset is not released.	Reset input terminals are not wired.	Correctly wire reset input terminals (between INT11 and INT12 or between INT21 and INT22). Use NC contact of forced guide type relay to assure the system safety.
	Relay is welded.	Replace the relay.
	The response time of relay is long.	Replace the relay with a one whose response time is appropriate.
	Rise-up reset signal has not been entered. (Manual)	Use a momentary switch. Replace the switch.

### <An error is displayed in the 7-segment indicator (red)>

Indication	Description	Cause	Remedy
E []	Set data error	Error due to data mismatch in internal memory	Connect this device to a PC and use the software tool to make factory settings. Refer to "5-21-1-2 Initialize Settings".
	Error in external	Error in voltage of power supply connected to external circuit pow- er supply (V2, G2)	Confirm the wiring, supply voltage and supply capacity of the external circuit power supply.
	circuit power supply (V2, G2)	The external power supply is not turned ON within 30 sec. after the internal power supply is turned ON.	Enter the external power supply within 30 sec. after the internal power supply is turned ON or turn ON the external power supply first.
E4	Safety input circuit error	Failure due to short-circuit be- tween safety input circuits	Confirm the wiring of safety inputs 1 to 8. Check for damage in the safety contacts or safety sensors in connection, and replace them, if necessary.
		When control output 1 / 2 is ON, it is short-circuited with 0 V or +V.	
		When control output 1 / 2 is OFF, it short-circuits with +V.	Correctly wire control output 1 / 2. Refer to "2-6 Wiring".
<b>E 5.</b> Control output circui error	Control output circuit error	Control output terminals short-circuit with each other or with other input / output lines.	Neier to 2-5 Willing .
		Excessive current flows in control output 1 / 2.	Current value should be within the specified control output 1 / 2. Refer to "8-1 Specifications".
		Output circuit error	Output circuit is damaged. Replace this device.
<i>E 5</i> .	Switch setting error	The mode selector switch (RUN / PROG) is located at the intermediate position.	Switch the mode selector switch to the correct position of RUN or PROG.
		DIP switch was changed during operation.	Confirm the settings of DIP switch.
E 7	Reset input circuit error	When the overall reset is set (one reset), signal enters both inputs 1 and 2.	Wire correctly.
E B.	Error in internal circuit current (V1, G1)	Error in voltage of power supply connected to internal circuit power supply (V1, G1)	Inspect the power supply and replace it.
EF.	Internal error	Internal failure	Contact our office.

<sup>\*1:</sup> Dots of 7-segment indicator (red) blink.

# **Chapter 8 Specifications / Dimensions**

# 8-1 Specifications

Model No.	SF-C21	
Supply Power supply for interna	24V DC:15 Ripple P-P 10% or less	
voltage Power supply for extern		
Current Power supply for interna		
consumption Power supply for extern		
Safety input (IN1 to IN8)	4 × 2 inputs Rated voltage: Same as voltage of internal power supply	
ON level		
	Input voltage: 18V, Input current: 3.5mA	
OFF level	Input voltage: 5V, Input current: 1.0mA	
Rated input current	Approx. 5mA	
Input impedance	Approx. 4.7kΩ	
Duration time of detectable Ol state	10ms or more	
OFF state	0.7ms or less	
Control output (OUT1 to OUT4)	PNP open-collector transistor with 2 outputs × 2  • Maximum source current: 300mA / output  • Applied voltage: Same as voltage of the power supply for external  • Residual voltage: 2.5V or less  • Leakage current: 100µA or less (Including power supply OFF condition)	
Output mode	True: ON, False: OFF	
ON delay function	Incorporated	
OFF delay function	Incorporated	
Short-circuit protection	Incorporated	
Response time	OFF response: 10ms or less, ON response: 100ms or less	
Response time	PNP open-collector transistor with output × 4	
Auxiliary output (AUX1 to AUX4) (Non-safety output)  Output mode	<ul> <li>Maximum source current: 60mA / output</li> <li>Applied voltage: Same as voltage of the power supply for external</li> <li>Residual voltage: 2.5V or less</li> <li>Leakage current: 100μA or less (Including power supply OFF condition)</li> <li>AUX1: Negative logic of OUT1 / OUT2 (ON when OUT1 / OUT2 is OFF)</li> <li>AUX2: Negative logic of OUT3 / OUT4 (ON when OUT3 / OUT4 is OFF)</li> </ul>	
(Factory defaults)	AUX3: Reset trigger output (ON under reset release wait condition) AUX4: Lockout output (OFF when lockout)  • Negative logic output of OUT1 / OUT2 (ON when OUT1 / OUT2 is OFF)	
Output mode  Any of the auxiliary outputs can be customized using the software tools	Negative logic output of OUT3 / OUT4 (ON when OUT3 / OUT4 is OFF) Positive logic output of OUT1 / OUT2 (ON when OUT1 / OUT2 is ON) Positive logic output of OUT3 / OUT4 (ON when OUT3 / OUT4 is ON) Outputs A, B, C, and D of diagnosis results of input blocks 1 to 4 (ON when logic is true) Outputs E, F, and G of internal logic circuit diagnostic results (ON when logic is true) Reset trigger output (ON under reset release wait condition) Lockout output (OFF when lockout) Muting indicator output (ON when muting / override)	
	Monitor output in response to IN1 to IN8 (ON when input)     No output (normally OFF)	
Short-circuit protection	Incorporated	
Response time	10ms or less	
	Semiconductor photo MOS relay output × 1  • Maximum load current: 60mA	
Muting indicator output	<ul> <li>Same as voltage of the power supply for internal</li> <li>Residual voltage: 2.5V or less</li> </ul>	
	<ul> <li>Same as voltage of the power supply for internal</li> <li>Residual voltage: 2.5V or less</li> <li>Leakage current: 100μA or less (Including power supply OFF condition)</li> </ul>	
Muting indicator output  Output mode Short-circuit protection	<ul> <li>Same as voltage of the power supply for internal</li> <li>Residual voltage: 2.5V or less</li> </ul>	


Model No.	SF-C21
Interlock function	Incorporated
Lockout release function	Incorporated
External device monitor function	Incorporated
Communication function (MODBUS RTU)	Interface: RS-485     Protocol: MODBUS RTU     Maximum transmission distance: 100m     Maximum number of units that can be connected: 8 units (slaves)
Logic selection function	<ul> <li>No.0: Customizable logic</li> <li>No.1: Overall stop control</li> <li>No.2: Parallel muting control</li> <li>No.3: Sequential muting control</li> <li>No.4: Partial stop control 1</li> <li>No.5: Partial stop control 2</li> <li>No.6: Two-hand control</li> <li>No.7: OR control</li> <li>No.8: Operation mode selection control</li> </ul>
Logic setting function	Input mode, control mode, output mode, reset mode, auxiliary output mode
Protection structure	IP20 (IEC) (Must surely be installed within a control panel whose protection structure is IP54 or more)
Working ambient temperature	-10 to +55°C (No dew condensation or icing allowed), Storage: -25 to +60°C
Working ambient humidity	30 to 85%RH, Storage: 30 to 85%RH
Voltage withstandability	1,000V AC for one min.  /All inputs connected together- USB port, all inputs connected together- RS-485 port, USB port - RS-485 port  Between all supply terminals connected together and enclosure, all outputs connected together - all input connected together, all outputs connected together - USB port  All outputs connected together - RS-485 port
Insulation resistance	20MΩ or more with 500V DC mega  /All inputs connected together- USB port, all inputs connected together- RS-485 port, USB port - RS-485 port  Between all supply terminals connected together and enclosure, all outputs connected together - all input connected together, all outputs connected together - USB port  All outputs connected together - RS-485 port
Vibration resistance	5 to 8.4Hz half amplitude of 3.5mm, 8.4 to 150Hz acceleration of 9.8m/s <sup>2</sup> (1G) (in X, Y and Z directions for two hours each) (IEC / EN 60068-2-6)
Shock resistance	147m/s² (15G) 11ms in X, Y and Z directions for three times each (IEC / EN 60068-2-27)
Pollution degree	2
Overvoltage category	II
Usable altitude	2,000m or less
Startup time after power on	2 sec. or less
PFH <sub>D</sub> (Probability of dangerous failure per hour)	9.73 × 10 <sup>-10</sup>
MTTF <sub>d</sub> (Mean time to dangerous failure)	100 years or more
DC <sub>avg</sub>	99%
SFF (Probability of safe failure)	99%
HFT (Hardware fault tolerance)	1
Mission time	20 years
Subsystem type	Type B (IEC 61508-2)
Maximum cable length	100m
Connection method	Input / output and power supply: Detachable spring cage terminal blocks RS-485: Detachable spring cage terminal block USB: MiniB male

# Specifications / Dimensions

Model No.		SF-C21
Material		Enclosure: PC / ABS alloy, Cover: PC
Weight		Approx. 190g
Detectable failure mode		Input short-circuits with 0V or +V Inputs short-circuit with each other or with other I/O Control output short-circuits with 0V or +V Control outputs short-circuit with each other or with other I/O Overcurrent flows in control output Internal circuit failure
Applicable standards	Safety	IEC 61508-1 to 7, EN 61508-1 to 7 (SIL3), ISO 13849-1 (Up to category 4, PLe) IEC 61131-2, IEC 61010-2-201, IEC 62061
Stanuards	EMC	IEC 61000-6-2, IEC 61326-3-1, EN 55011
Related stand	ards	IEC 60947-1, IEC 60947-5-1, IEC 60947-5-2, IEC 60947-5-5, IEC 60947-5-8 IEC 61496-1, IEC TS 62046, ISO 13851

Note: Do not use or store this device in a pressurized environment beyond the atmospheric pressure at the sea level.

### 8-2 Dimensions



# **Chapter 9 Others**

# 9-1 Glossary

	Safety directive which applies to machines shipped to EU region.
Machinery Directive	This directive is for an assembly of linked parts or components, at least one of which moves and co-operates for a specific purpose, and in which a drive system is incorporated or intended to be incorporated.
	The directive is for electromagnetic compatibility, which applies to any electronic devices shipped to EU region.
EMC Directive	Electronic devices have a possibility of "EMI or emission," which has them play a role of noise source affecting other electric devices, and a possibility of "EMS or immunity," which has them affected by noise generated by surrounding electronic devices.  EMC means that electronic devices achieve not only reduction of electromagnetic energy emitted, conducted or propagated by themselves, but also resistance to electromagnetic energy generated by surrounding electronic devices.
	The standards that pertain to general functional safety for electrical, electronic, and programmable electronic devices.
IEC 61508-1 to 7 JIS C 0508-1 to 7	These standards are provided intended to serve as basic and mechanical safety standards that are applicable for various types of industries.  Functional safety is defined as the "totally safe part that associates EUC (Equipment under control) and ECU control with a system depending on correct functioning of safety-related system of E/E/PE (electrical/electronic/programmable electronic), other technology safety related systems, and external risk reduction equipment."
EN 55011	Limits and methods of measurement of radio disturbance characteristics of industrial, scientific and medical (ISM) equipment.
FSD	The abbreviation for Final Switching Device. Components of a safety-related control system of a machine that cuts off the circuit of main element of the machine when control output is turned OFF.
Lockout status	Status in which this device cannot operate normally. In this status, the lockout signal turns OFF all control outputs.

### 9-2 CE Marking Declaration of Conformity

### Itemized Essentials of EU Declaration of Conformity

**Manufacturer's Name:** Panasonic Industrial Devices SUNX Co., Ltd. **Manufacturer's Address:** 

2431-1, Ushiyama-cho, Kasugai, Aichi 486-0901, Japan

#### **EU Representative's Name:**

Panasonic Marketing Europe GmbH Panasonic Testing Center

EU Representative's Address: Winsbergring 15, 22525 Hamburg, Germany

Product: Safety Control Unit Model Name: SF-C21 Trade Name: Panasonic

### **Application of Council Directive:**

- 2006/42/EC Machinery Directive
- 2004/108/EC EMC Directive
- 2011/65/EU RoHS Directive

#### Tested according to:

- IEC 61131-2: 2007
- IEC 61010-2-201: 2013
- -IEC 61508-1: 2010
- IEC 61508-2: 2010
- IEC 61508-3: 2010
- IEC 61508-4: 2010
- EN ISO 13849-1: 2008
- -EN 62061: 2005
- -EN 55011: 2009 +A1: 2010
- -EN 61000-6-2: 2005
- -EN 50581: 2012

Type Examination: Certified by TÜV SÜD Product Service GmbH Ridlerstrasse

65 80339 München Germany

### Revision History First edition

First edition October 31, 2014

#### 1. WARRANTIES:

- (1) Subject to the exclusions stated in 2 (EXCLUSIONS) herein below, Panasonic Industrial Devices SUNX warrants the Products to be free of defects in material and workmanship for a period of one (1) year from the date of shipment under normal usage in environments commonly found in manufacturing industry.
- (2) Any Products found to be defective must be shipped to Panasonic Industrial Devices SUNX with all shipping costs paid by Purchaser or offered to Panasonic Industrial Devices SUNX for inspection and examination. Upon examination by Panasonic Industrial Devices SUNX, Panasonic Industrial Devices SUNX will, at its sole discretion, repair or replace at no charge, or refund the purchase price of, any Products found to be defective.

#### 2. EXCLUSIONS:

- (1) This warranty does not apply to defects resulting from any cause:
  - (i) which was due to abuse, misuse, mishandling, improper installation, improper interfacing, or improper repair by Purchaser;
  - (ii) which was due to unauthorized modification by Purchaser, in part or in whole, whether in structure, performance or specification;
  - (iii) which was not discoverable by a person with the state-of-the-art scientific and technical knowledge at the time of manufacture;
  - (iv) which was due to an operation or use by Purchaser outside of the limits of operation or environment specified by Panasonic Industrial Devices SUNX;
  - (v) which was due to normal wear and tear;
  - (vi) which was due to Force Majeure; and
  - (vii) which was due to any use or application expressly discouraged by Panasonic Industrial Devices SUNX in 4 (CAUTIONS FOR SAFE USE) hereunder.
- (2) This warranty extends only to the first purchaser for application, and is not transferable to any person or entity which purchased from such purchaser for application.

#### 3. DISCLAIMERS

- (1) Panasonic Industrial Devices SUNX's sole obligation and liability under this warranty is limited to the repair or replacement, or refund of the purchase price, of a defective Product, at Panasonic Industrial Devices SUNX's option.
- (2) THE REPAIR, REPLACEMENT, OR REFUND IS THE EXCLUSIVE REMEDY OF THE PURCHASER, AND ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING, WITHOUT LIMITATION, THE WARRANTIES OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE, AND NON-INFRINGEMENT OF PROPRIETARY RIGHTS, ARE HEREBY EXPRESSLY DISCLAIMED. IN NO EVENT SHALL PANASONIC INDUSTRIAL DEVICES SUNX AND ITS AFFILIATED ENTITIES BE LIABLE FOR DAMAGES IN EXCESS OF THE PURCHASE PRICE OF THE PRODUCTS, OR FOR ANY INDIRECT, INCIDENTAL, SPECIAL OR CONSEQUENTIAL DAMAGES OF ANY KIND, GENERAL TERMS AND CONDITIONS 4 OR ANY DAMAGES RESULTING FROM LOSS OF USE, BUSINESS INTERRUPTION, LOSS OF INFORMATION, LOSS OR INACCURACY OF DATA, LOSS OF PROFITS, LOSS OF SAVINGS, THE COST OF PROCUREMENT OF SUBSTITUTED GOODS, SERVICES OR TECHNOLOGIES, OR FOR ANY MATTER ARISING OUT OF OR IN CONNECTION WITH THE USE OR INABILITY TO USE THE PRODUCTS.

#### 4. CAUTIONS FOR SAFE USE

- (1) The applications shown in the catalogue are only suggestions, and it is Purchaser's sole responsibility to ascertain the fitness and suitability of the Products for any particular application, as well as to abide by Purchaser's applicable local laws and regulations, if any.
- (2) Never use the Products NOT rated or designated as "SAFETY SENSOR" in any application involving risk to life or property. When such a use is made by Purchaser, such Purchaser shall indemnify and hold harmless Panasonic Industrial Devices SUNX from any liability or damage whatsoever arising out of or in relation to such use.
- (3) In incorporating the Products to any equipment, facilities or systems, it is highly recommended to employ fail-safe designs, including but not limited to a redundant +++design, flame propagation prevention design, and malfunction prevention design so as not to cause any risk of bodily injury, fire accident, or social damage due to any failure of such equipment, facilities or systems.
- (4) The Products are each intended for use only in environments commonly found in manufacturing industry, and, unless expressly allowed in the catalogue, specification or otherwise, shall not be used in, or incorporated into, any equipment, facilities or systems, such as those:
  - (a) which are used for the protection of human life or body parts;
  - (b) which are used outdoors or in environments subject to any likelihood of chemical contamination or electromagnetic influence;
  - (c) which are likely to be used beyond the limits of operations or environments specified by Panasonic Industrial Devices SUNX in the catalogue or otherwise;
  - (d) which may cause risk to life or property, such as nuclear energy control equipment, transportation equipment (whether on rail or land, or in air or at sea), and medical equipment;
  - (e) which are operated continuously each day for 24 hours; and
  - (f) which otherwise require a high level of safety performance similar to that required in those equipment, facilities or systems as listed in (a) through (e) above.

#### 5. EXPORT CONTROL LAWS

In some jurisdictions, the Products may be subject to local export laws and regulations. If any diversion or re-export is to be made, Purchaser is advised to abide by such local export laws and regulations, if any, at its own responsibility.

Panasonic Industrial Devices SUNX Co., Ltd.

■ Overseas Sales Division (Head Office): 2431-1 Ushiyama-cho, Kasugai-shi, Aichi, 486-0901, Japan
■ Telephone: +81-568-33-7861 ■ Facsimile: +81-568-33-8591 Please contact .....

panasonic.net/id/pidsx/global

About our sale network, please visit our website.